



HARVEY PUBLIC SCHOOLS DISTRICT 152
Buildings and Grounds
Report
February 2018
“Ensuring High Levels of Learning for All”

Class/Field School: Fire alarm panel installed. Completed more reprogramming fire panel on 1/31/18

Inspected fire alarm/alarm with Sonitrol Vendor 1/31/18.

Coil repaired to gym room and hallway near lunchroom area.

Replaced tile in various areas

Corrected sliding door in existing room used by Illinois Action for Children. Completing punch list for Illinois Action for Children Inspection held March 2, 2018.

Maya Angelou School: On going reprogramming fire panel completed 1/31/18.

Tested Fire Panel and Fire Alarm. Test completed and is in working condition.

Sonitrol: Inspections performed for Fire Alarms and Fire Panels January 18, 2018 Sonitrol Brooks Middle, Bryant, Whittier, Riley, and Holmes.

Class/ Fields and Maya Angelou will be scheduled once new fire alarm panels have been replaced.

Riley: IT room has painted on 1/5/18. Tile replaced for missing pieces 1/3/18. Carpet installed 1/9/18

New pipe and wire 120v/20a circuits and receptacles’.

Installed 208v/20a multi wire circuit to power new air condition unit for Room 116(IT room)

All circuits fed from service panel on stage gymnasium

Note DATA lines requested per Teaching and Learning Director for IT Services

Addendum: Note worked was completed during weekend 1/20/18-1/21/18 to ensure Riley Central Office would not lose pressure to boilers. Found 7 breaks that were previous patched over several years. Recommendation to completely take out old line and replace to ensure entire main waterline would work properly. Note line has never been replaced.





HARVEY PUBLIC SCHOOLS DISTRICT 152
Buildings and Grounds
Report
February 2018
“Ensuring High Levels of Learning for All”



Administrative Center ~ 16001 Lincoln Avenue, Harvey, Illinois 60426 ~ (708) 333-0300 ~ Fax (708) 333-0349

ANGELOU • BRYANT • HOLMES • RILEY • SANDBURG • WHITTIER • BROOKS MIDDLE SCHOOL



HARVEY PUBLIC SCHOOLS DISTRICT 152
Buildings and Grounds
Report
February 2018
“Ensuring High Levels of Learning for All”

Sandburg Elementary School:



Picture of old water main line Sandburg December. 27, 2017. New water main in area.

Area has been filled and monitored until weather breaks. Note area scheduled to be asphalt in springtime by vendor Weathersby & Sons

Bryant School: Fan coil unit changed on Rooftop unit #9 and #6 not. Mainframe of board rebuilt by Johnson Controls Completed Jan 2018.

Note MVHEATING and Johnson Controls worked jointly to complete task to ensure task was completed properly and tested equipment to work correctly.

Brooks: Windows to be changed out 6 entry doors to be changed (TBD)

Kitchen hot water tank down on 1/3/18. Installed hot water pump 1/4/18.

Maya Angelou School: Windows to be changed out 4 entry doors. Quote TBD

Brooks Middle School: Pneumatic heaters inspected, checking for dampers operable and closures for regulating heat. Currently return air is heating school.

Scheduling Spring break Cleaning

Whittier and Bryant: Sprinkler System Inspected completed

Prepared by Nichae' Whitenhill, Director of Buildings and Grounds