

Southeast Extinguisher Service Inc.

8319 Airport Blvd
Juneau AK 99801
907-790-2522

Fire Extinguishers

Service History

Order # 35482

JOB LOCATION

Craig City School District
Craig Elementary School
100 School Road
Craig AK 99921
Service Date: 10/7/2023

P1: 826.3274

CLIENT

Craig City School District
Craig Elementary School
PO Box 800
Craig AK 99921

CONTACT

TECHNICIAN

SF

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 AT279731	Headstart Front Door	5 ABC	2011		2017	AT279731	*** Inspected/Service Required ***10/6/2023 4:01:43 PM
2 ZU967159	Headstart Back Door	10 ABC	2008		2015	ZU967159	*** Inspected/Service Required ***10/6/2023 4:03:08 PM
3 AB691744	Kitchen	6 Class K	2008	2023*		AB691744	10/7/2023 4:14:49 PM
4 S559274	Spare	13.15 HALON 1211	1990	2015		S559274	*** Failed ***
5 S559281	Spare	13.15 HALON 1211	1990			S559281	*** Failed ***
6 BG289993	Basement	10 ABC	2012	2023*		BG289993	10/7/2023 4:32:54 PM
7 AP528325	Hall by Office	10 ABC	2011	2023*		AP528325	10/7/2023 4:19:20 PM
8 GA321181	Hall by Bathrooms	10 ABC	1986	2023*		GA321181	

Extinguisher Work Summary as of 10/7/2023

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	5 Year Visual	Other	Totals
10 ABC	3	0	0	0	0	0	0	1	4
5 ABC	0	0	0	0	0	0	0	1	1
6 Class K	1	0	0	0	0	0	0	0	1
13.15 HALON 1211	0	0	0	0	0	0	0	2	2
Totals	4	0	0	0	0	0	0	4	8

Deficiency Report

Num	S/N	Bar Code	Deficiency	Status	Comment
4	S559274	S559274	6 Year Due Unserviceable	Open	
5	S559281	S559281	6 Year Due Unserviceable	Open	

Annual Fire Extinguisher Inspection

I. NFPA 10

PASS FAIL NA

Maintenance and Inspection of fire extinguishers shall include a check of at least the following items:

- 1. Located in designated place NFPA 10 6.1.2 - 6.1.3 & 7.2.2(1)
- 2. No obstructions to access or visibility NFPA 10 6.1.3.3 & 7.2.2(2)(3)

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Southeast Extinguisher Service Inc.

8319 Airport Blvd
Juneau AK 99801
907-790-2522

Fire Extinguishers

Service History

Order # 35482

JOB LOCATION

Craig City School District
Craig Elementary School
100 School Road
Craig AK 99921

P1: 826.3274

CLIENT

Craig City School District
Craig Elementary School
PO Box 800
Craig AK 99921

Annual Fire Extinguisher Inspection

I. NFPA 10

	PASS	FAIL	NA
3. Operating instructions on nameplate legible and facing outward NFPA 10 7.3.2.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Pull pin operates correctly and new tamper seal installed NFPA 10 7.3.2.2 - 7.3.2.2.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Fullness determined by weighing or "hefting." NFPA 10 7.3.2.1 & 7.2.2(5)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. Examined for obvious physical damage, corrosion, leakage, or clogged nozzle NFPA 10 7.3.2.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. Pressure gauge reading or indicator in the operable range or position NFPA 10 7.2.2(4)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. Extinguisher properly protected from physical damage such as from impact, vibration or environment NFPA 10 6.1.3.7	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Correct extinguisher for application NFPA 10 5.1-5.6	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Correct hanger or bracket NFPA 10 6.1.3.4	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11. Hanger or bracket secure and mounted at correct height NFPA 10 6.1.3.4 - 6.1.3.8	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12. For wheeled units, the condition of the tires, wheels, carriage, hose, and nozzle checked NFPA 10 7.7 & 7.2.2(6)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

II. Action Recommended/Coverage Notes

	OK	FAIL	NA
1. Property has proper coverage	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Delicate electronic equipment has proper coverage NFPA 5.5.6	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3. Additional notes on inspection	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

The maintenance and recharging of fire extinguishers is based on NFPA 10-2010, 7.1.2; 7.2.2; 7.2.4; 7.3.1, Installation of Portable Fire Extinguishers, and Alaska statutes and is approved by the local Authority Having Jurisdiction. This inspection is not an engineering evaluation of the fire extinguishers.

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

Southeast Extinguisher Service Inc.

8319 Airport Blvd
Juneau AK 99801
907-790-2522

Fire Extinguishers

Service History

Order # 35482

JOB LOCATION

Craig City School District
Craig Elementary School
100 School Road
Craig AK 99921

P1: 826.3274

CLIENT

Craig City School District
Craig Elementary School
PO Box 800
Craig AK 99921

Exhibits



FE #3 - Bad Valve Assembly

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS