

MAINTENANCE REPORT
NOVEMBER 2019

Submitted by: Reid Reagan

Maintenance staff has been busy plowing snow, each and every worker is very appreciative to the School Board/District for the new Case 321 Loader, a great addition to our work force. We have responded to 107 work orders, all repairs or service calls.

HIGH SCHOOL:

Staff assisted with the setup and cleanup of the Night of Lights. Installed new workout equipment in wrestling room and shelves with hooks to referee's room. Pierce Flooring installed new vinyl plank flooring in gym lobby, health room and hall.

BMS:

Replaced faulty actuator that supplies heat to the entrance and office area. Trane diagnosed and repaired roof unit that heats kitchen and cafeteria, changed belts and filters.

NAPI:

Installed new drive shaft to roof air-handler, changed belts. Installed new heating coils in wall unit. Big Sky Elevator repaired elevator.

BES:

Nothing major to report, mostly getting heat to cold rooms, sometimes it involves adjusting thermostat.

KWB:

Reset tripped switch to ceiling heat unit in the gym, installed new flat panel TVs.

VC:

Installed new flat panel TVs.

TRANSPORTATION:

Installed new water bottle filling station in break room.