Southeast Extinguisher Service Inc.

8319 Airport Blvd Juneau AK 99801 907-790-2522 Fire Extinguishers
Service History

Order # 37109

JOB LOCATION

Craig City School District Craig Middle School 100 School Road Craig AK 99921

Service Date: 8/15/2024

CONTACT

CLIENT

Craig City School District Craig Middle School PO Box 800 Craig AK 99921

TECHNICIAN

CM

Num S/N		Location	Size /	Type	Mfg I	Date Hydr	o Test	6 Year	Bai	r Code	Timestamp	
1 R671	1 R671875 Tech Ed Classroom		20	HALON 1211	1990	2013			R6	71875	*** Failed ***	
2 F48695356 Bottom of Stair		Bottom of Stairs	10	ABC	2018			2024*	F48	8695356	8/15/2024 2:16:1	9 PM
3 F48695357 Main Entrance		Main Entrance	10	ABC	2018			2024*	F48	8695357	8/15/2024 2:15:5	0 PM
4 S417	537	Boiler Room	9	HALON 1211	1990	2013			S4	17537	*** Failed ***	
5 MP66	9744	Gym Boiler Spare	10	ABC	1995	2023			MP	P-669744	8/15/2024 10:07:	12 AM
6 NM-4	6 NM-435556 Modular 1		5	ABC	1996	2023			NM	1-435556	8/15/2024 9:53:4	0 AM
7 MD-877368 Modular 2		Modular 2	10	ABC	1994	2023			ME)-877368	8/15/2024 9:55:4	1 AM
8 MH96	8 MH969180 Modular 4		10	ABC	1994	2023			MH	I-969180	8/15/2024 9:51:3	1 AM
9 HU23	9 HU239610 Gym by Office		20	ABC	1988	2023	2023		HU239610		8/15/2024 10:33:42 AM	
10 BG28	39997	Boiler Room	10	ABC	2012	2024	*		BG	289997	8/15/2024 2:12:2	9 PM
11 RJ81	0978	Gym by Boy's Locker Room	10	ABC	2000	2024	*		RJ.	-810978	8/15/2024 2:14:2	4 PM
12 LV-05	57188	Back Hall	10 ABC		1993	2013		2019	LV	-057188	*** Failed ***8/15/2024 10:09:40 AM	
13 H98063515 Back Hall		10	ABC	2023				H9	8063515	8/15/2024 10:23:	40 AM	
14 12054	3602	Boiler Room	11 HALOTRO N		2024				120	543602	8/15/2024 10:14:	35 AM
15 MZ-5	65896	Weight Room	10	ABC	1995	2024	*		MZ	<u>-</u> 565896	8/15/2024 2:15:0	9 PM
Extinguish	er Wo	rk Summary as	of 8/15	5/2024								
		Hydro Test	6 Year	Annua	al M	Monthly	Rechar	ge	New	5 Year Visual		Totals
10	ABC	3	2		4	0		0	0	0	1	10
20	ABC	0	0		1	0		0	0	0	0	1
5	ABC	0	0		1	0		0	0	0	0	1
20 HA	ALON 1211	0	0		0	0		0	0	0	1	1
9 HALON		0	0		0	0		0	0	0	1	1
11 HALOTRON		0	0		0	0		0	1	0	0	1
Totals		3	2		6	0		0	1	0	3	15
Deficienc	y Rep	oort										
Num	S/		Bar Cod	_	eficien			Status		Comment		

Southeast Extinguisher Service Inc.

8319 Airport Blvd Juneau AK 99801 907-790-2522 Fire Extinguishers Service History Order # 37109

JOB LOCATION

Craig City School District Craig Middle School 100 School Road Craig AK 99921

CLIENT

Craig City School District Craig Middle School PO Box 800 Craig AK 99921

Num	S/N	Bar Code	Deficiency	Status	Comment
1	R671875	R671875	Hydro Due	Open	Unservicable
4	S417537	S417537	Hydro Due	Open	Unservicable
12	LV-057188	LV-057188	Excessive Rust	Open	

Annual Fire Extinguisher Inspection

I. NF	PA 10	PASS	FAIL	NA
Maii	ntenance and Inspection of fire extinguishers shall include a check of at least the following items	!		
1.	Located in designated place NFPA 10 6.1.2 - 6.1.3 & 7.2.2(1)	···		
2.	No obstructions to access or visibility NFPA 10 6.1.3.3 & 7.2.2(2)(3)	~		
3.	Operating instructions on nameplate legible and facing outward NFPA 10 7.3.2.1	~		
4.	Pull pin operates correctly and new tamper seal installed NFPA 10 7.3.2.2 - 7.3.2.2.2	~		
5.	Fullness determined by weighing or "hefting." NFPA 10 7.3.2.1 & 7.2.2(5)	~		
6.	Examined for obvious physical damage, corrosion, leakage, or clogged nozzle NFPA 10 7.3.2.1	~		
7.	Pressure gauge reading or indicator in the operable range or position NFPA 10 7.2.2(4)	~		
8.	Extinguisher properly protected from physical damage such as from impact, vibration or environment NFPA 10 6.1.3.7	~		
9.	Correct extinguisher for application NFPA 10 5.1-5.6	~		
10.	Correct hanger or bracket NFPA 10 6.1.3.4	~		
11.	Hanger or bracket secure and mounted at correct height NFPA 10 6.1.3.4 - 6.1.3.8	~		
12.	For wheeled units, the condition of the tires, wheels, carriage, hose, and nozzle checked NFPA 10 7.7 & 7.2.2(6)			~
II. A	ction Recommended/Coverage Notes	OK	FAIL	NA
1.	Property has proper coverage	~		
2.	Delicate electronic equipment has proper coverage NFPA 5.5.6	···		
3.	Additional notes on inspection			~

The maintenance and recharging of fire extinguishers is based on NFPA 10-2010, 7.1.2; 7.2.2; 7.2.4; 7.3.1, Installation of Portable Fire Extinguishers, and Alaska statutes and is approved by the local Authority Having Jurisdiction. This inspection is not an engineering evaluation of the fire extinguishers.

Southeast Extinguisher Service Inc.

8319 Airport Blvd Juneau AK 99801 907-790-2522

Fire Extinguishers Service History

Order # 37109


JOB LOCATION

Craig City School District Craig Middle School 100 School Road Craig AK 99921

CLIENT

Craig City School District Craig Middle School PO Box 800 Craig AK 99921

Exhibits



FE #12 - Rust