

Maintenance Report

July 18, 2017

Submitted by: Glen Hall

BHS: Plumber is draining and flushing water heaters. Repairing elbow on one of booster pumps. Boiler men addressing circ pump issue in the Vo-Tech side changing out a control.

VC: Maintenance Painter in gym area doing touch up throughout the building. Also painting stairs.

KWB: Boiler man repairing flue on #2 Boiler. Changing out transformer on #2 Boiler being done in-house. Painter torching up throughout school building.

BES: Advertising for painter to paint classrooms.

NAPI: Helping clean up downstairs tunnel area.

BMS: Replacing control unit on chiller. Trane is doing the work. Installing duct work on Intake air so it can be filtered. Work being done in-house. Installing louver's in kitchen ceiling to help with air flow which will help condensing unit on freezer stay cooler.

BABB: Repairing all exterior lights around building. Refinishing gym floor and look at heating issue in gym.

The maintenance department has been very busy with grounds work, watering lawns and trash pickup.

Grime Stoppers came and cleaned all overhead exhaust hoods in all the kitchens throughout all the schools.