



Date: September 8th, 2026
To: East Aurora School District 131 Board of Education
From: Andrew Allen, Assistant Superintendent of Operation
Subject: Emergency Allen Storm Sewer Repair

BACKGROUND

This Summer there will multiple occurrences of pooling and standing water in the courtyard of Allen Elementary school. The water and moisture did not recede as expected.

SUMMARY

We contacted our partner vendor Fox Valley Sewer to jet the line to hopefully remove the issue. During this process their jet got stuck along with the camera. We contacted Stokes Construction, who has completed work for us in the past to excavate the area outside of Door 3 to find the issues and retrieve the stuck equipment. Stokes has found a buried storm sewer manhole that had partially collapse. This work is in the process of being completed, but we found additional issues further down the line towards where we attach to the main sewer for the city. We are going to need additional work to fix the line 100ft from the road.

FINANCIAL IMPACT

District funds would be used for this project. Currently on a T&M rate with Stokes Construction to complete the project.