

DEPT. OF FACILITIES
CONSTRUCTION REPORT
MAY 2018

Submitted by: Reid Reagan

HIGH SCHOOL:

Tim Petersen of L'Heureux Page Werner has been in contact with Morrison Maierle about a solution to the leaking roof caused by the louver on the new addition, they suggested installing a water collection system where water/snow is coming in through the louver and going down the duct work into the classrooms/hallway.

KWB:

Tim Petersen also submitted as built drawings for the sprinkler system installed last summer at KWB by Jonas Sprinklers, so we can install the new playground equipment without damaging the sprinkler system.

MIDDLE SCHOOL:

Big Sky Elevator has suggested a MOD on the elevator, replacing the electronics with an up-to-date system similar to the overhaul just done to the Napi elevator.