



SOUTH SAN ANTONIO INDEPENDENT SCHOOL DISTRICT

Agenda Item Summary

Meeting Date: 5/18/16

Purpose:  Report Only  Recognition  Discussion/ Possible Action

Presenter(s): Jenny Arredondo, Executive Director of Business Operations & Technology  
Christina Welch, Director of Child Nutrition

Item Title:

Discussion and possible action to approve the purchase and installation of a walk in cooler/freezer combination unit at Five Palms Elementary. The new unit will ensure proper temperature and storage of cold foods and will maintain the food safety program set in place for meals served to students.

Description:

The purchase and installation of a combination cooler/freezer walk in unit at Five Palms Elementary School from Reliance Air and Refrigeration utilizing the Region 20 coop Bid #2120. The current unit has experienced re-occurring repair issues. The purchase will be in the amount of \$43,872.96 including installation and shelving.

District Goal:

Goal 6 We will promote and ensure a safe and secure learning environment for all students.

Funding Budget Code and Amount:

CFO Approval

101-35-6639-00-xxx-699-000 - \$43,872.96

APPROVAL ROUTE

SIGNATURE

DATE

Principal/Director:

5/6/16

Executive Director:

5/6/16

Chief Administrator:

5/6/16

Superintendent:

5-13-2016

**Proposal Date:** 4/7/2016

**Proposal #:** 1250

**Project:**

**Bill To:**

SSISD Fivepalms E.S.  
 7138 Fivepalms  
 San Antonio, TX 78242

Description	Est. Hours/Qty.	Rate	Total
FREEZER WITH FLOOR 10' X 7'8" X 7'7" HIGH O.D. COOLER WITH FLOOR 6' X 7'8" X 7'7" HIGH O.D. UL LABELED, NSF/USDA APPROVED (REF#: Q232037-001) Panel Insulation Insulation - 5" Insulframe Panel Components Ext Finish - White Emb Galv 26 ga - Mesa Walls Ext Roof Finish - Natl Emb. Galvanize 26 ga. Ext Finish - White Emb. Galvanize 26 ga. Doors Int Finish - White Emb. Galvanize 26 ga. Walls and Ceiling 1 Interior Floor - 4" Ramp NSF Non-Wood 080 ADT Floor Finish - .050 Smooth Aluminum 1/2" OSB Under Metal on Floor Lock Down Floors - Insulframe Lock Down Tops - Insulframe Manufactured Doors 1 Inset Cooler Door 3'0" x 6'8" 1 Inset Freezer Door 3'0" x 6'8" Door Accessories Kick Plates DT Aluminum 36" High on Int/Ext Man Door Leaf 2 2 Jamb K-1094 Guards Closer - Stainless Assy - Offset Steel 6 K1248 Hinge 2 Latch K-78 Assy W/O Lkng Cylinder w/ISR Qty Description Price 1 S.S. Locking Bar (to 60") On With Exterior Inside Door. Saftely Padlock Release by owner Walk-In Accessories 1 Vent - 1825 - 5" Angle-Seismic 26ga Tie Downs 1.5x1.5xCont Secure walls to tops on interior Angle Secure Tie Walls/Floor Down 18 ga galv to slab (1-1/2x6) 20 Sealant XB 9500 - White		0.00	0.00

**Total**

**Proposal Date:** 4/7/2016  
**Proposal #:** 1250  
**Project:**

**Bill To:**

SSISD Fivepalms E.S.  
7138 Fivepalms  
San Antonio, TX 78242

Description	Est. Hours/Qty.	Rate	Total
Seal Exterior Joints and around roof Other Roof Membrane 1 Structural by Durolast Steel White Roof Support 2 post and 1 beam over cooler door on interior Tapered Foam Roof			
<b>Total</b>			

**Proposal Date:** 4/7/2016  
**Proposal #:** 1250  
**Project:**

**Bill To:**

SSISD Fivepalms E.S.  
 7138 Fivepalms  
 San Antonio, TX 78242

Description	Est. Hours/Qty.	Rate	Total
<p>REFRIGERATION            (REF#: Q232037-002) Refrigeration X 7'7"            for 35 Deg Indoor Cooler, 6' X 7'8"            Outdoor, Air Cooled Pre-Assembled Remote 1 Model #:            RFH080E44DA Condensing Unit, 3/4 HP,            Medium Temp, Hermetic, R-404A/R-507, Suction            Temp: 208-230/1Ph, +22.8, 5,916 MCA: BTUH, 13.10,            Ambient: Shp Wgt: 110 156            deg,            Standard Components: Weather Cover Filter/Drier &amp;            Sight Glass Air Defrost Timer Crank. Headmaster            Heater Control            H.            PSC Condenser Fan Motors 1 Model #: AA16-58BAE            Evaporator , Medium Temp,            Temp Diff: 10.2, R-404A/R-507, 5,916 BTUH, Suction            Temp: +20, 115V, Evap Fan Amp: 0.90, Standard Shp            Wgt: Components:            40            Mounted Liquid Line Solenoid Valve Mounted            Expansion Valve Mounted Thermostat EC L -            Evaporator LOADED KIT motors            Five Year Extended Compressor Warranty \$ 105.00</p> <p>Refrigeration for -10 Deg Indoor Freezer, 10' x            7'8" x 7'7"            Outdoor, Air Cooled Pre-Assembled Remote 1 Model #:            RFH200L44DA Condensing Unit, 2 HP, Low            Temp, Hermetic, R-404A/R-507, Suction Temp: -22,            6,000 BTUH, Ambient: 110 deg, 208-230/1Ph, MCA:            Standard 32.30, Shp Components:            Wgt: 243            Weather Cover Filter/Drier &amp; Sight Glass Electrical</p>		0.00	0.00
<b>Total</b>			

**Proposal Date:** 4/7/2016  
**Proposal #:** 1250  
**Project:**

**Bill To:**

SSISD Fivepalms E.S.  
 7138 Fivepalms  
 San Antonio, TX 78242

Description	Est. Hours/Qty.	Rate	Total
Defrost Timer Crank. Heater H. Headmaster ED-10 Electric Control Defrost Kit PSC Condenser Fan Motors 1 Model #: AE26-60BDE Evaporator , Low Temp, Temp Diff: 10.0, R-404A/R-507, 6,000 BTUH, Suction Temp: -20, 208-230/1PH, Evap Fan Amp: 0.90, Def Standard Heat Amp: Components: 7.00, Shp Wgt: 54 Mounted Liquid Line Solenoid Valve Mounted Expansion Valve Mounted Thermostat EC L - Evaporator LOADED KIT Motors			
<b>Total</b>			

**Proposal Date:** 4/7/2016  
**Proposal #:** 1250  
**Project:**

**Bill To:**

SSISD Fivepalms E.S.  
 7138 Fivepalms  
 San Antonio, TX 78242

Description	Est. Hours/Qty.	Rate	Total
Metro MQ1854G MetroMax Q 18" x42" Shelf Metro MQ1854G MetroMax Q 18" x 48" Shelf Metro MQ1854G MetroMax Q 18" x 54" Shelf Metro MQ1854G MetroMax Q 18" x 60" Shelf Metro MQ1854G MetroMax Q 18" x 74" Shelf		0.00	0.00
will also pour 8 ft concret slab to tie into existing slab for walkin.		0.00	0.00
Will install new breaker for walkin cooler along with wire and hardware.		0.00	0.00
Existing walkin will be removed along with old fencing in area.Slab will be preped along with new slab and unit will then be installed.Water proof roof will be installed to new unit and sealed . All panels will be sealed ,all electrical performed to walkin and all refrigeration installed aswell.		43,872.96	43,872.96
<b>Total</b>			<b>\$43,872.96</b>