

LAB FEDERAL ID#:		ID00013	
DATE RECEIVED:		DATE REPORTED BY LAB:	
8/12/2016		8/24/2016	
COMPLIANCE SAMPLE:	YES	REPLACEMENT SAMPLE:	NO
SAMPLE TYPE:			
PWS #:	PWS NAME:		
	PENDLETON SCHOOL DISTRICT		
CONTACT NAME:		CONTACT PHONE:	
TABLE ROCK ANALYTICAL LAB			



Anatek Labs, Inc.

1282 Alturas Drive
 Moscow, ID 83843
 (208) 883-2839
 FAX 882-9246
 moscow@anateklabs.com

504 E. Sprague Ste. D
 Spokane, WA 99202
 (509) 838-3999
 FAX 838-4433
 spokane@anateklabs.com

www.anateklabs.com

Lead Analysis Report

Lab Sample #	Sample Location	Collection Date / Time	Analyte	Result	Method	Analysis Date	Analyst	Qualifier
160815007-001	160811A1 / MCKAY 4	8/11/2016 6:16 AM	Lead	0.0102	EPA 200.8	8/19/2016	ETL	
160815007-002	160811A2 / MCKAY 5	8/11/2016 6:18 AM	Lead	0.0194	EPA 200.8	8/19/2016	ETL	
160815007-003	160811A3 / MCKAY 6	8/11/2016 6:21 AM	Lead	0.0162	EPA 200.8	8/19/2016	ETL	
160815007-004	160811A4 / MCKAY 7	8/11/2016 6:24 AM	Lead	0.0165	EPA 200.8	8/19/2016	ETL	
160815007-005	160811A5 / MCKAY 8	8/11/2016 6:25 AM	Lead	0.0412	EPA 200.8	8/19/2016	ETL	
160815007-006	160811A6 / MCKAY 9	8/11/2016 6:26 AM	Lead	0.0495	EPA 200.8	8/19/2016	ETL	
160815007-007	160811A7 / MCKAY 10	8/11/2016 6:28 AM	Lead	0.00645	EPA 200.8	8/19/2016	ETL	
160815007-008	160811A8 / MCKAY 11	8/11/2016 6:29 AM	Lead	0.109	EPA 200.8	8/19/2016	ETL	
160815007-009	160811A9 / MCKAY 12	8/11/2016 6:31 AM	Lead	0.0249	EPA 200.8	8/19/2016	ETL	
160815007-010	160811A10 / MCKAY 13	8/11/2016 6:33 AM	Lead	0.0499	EPA 200.8	8/19/2016	ETL	
160815007-011	160811A11 / MCKAY 14	8/11/2016 6:34 AM	Lead	0.0864	EPA 200.8	8/19/2016	ETL	
160815007-012	160811A12 / MCKAY 15	8/11/2016 6:35 AM	Lead	0.0424	EPA 200.8	8/19/2016	ETL	
160815007-013	160811A13 / MCKAY 16	8/11/2016 6:40 AM	Lead	0.0954	EPA 200.8	8/19/2016	ETL	
160815007-014	160811A14 / MCKAY 17	8/11/2016 6:39 AM	Lead	0.731	EPA 200.8	8/19/2016	ETL	

Comments:

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595
 Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

LAB FEDERAL ID#: ID00013	
DATE RECEIVED: 8/12/2016	DATE REPORTED BY LAB: 8/24/2016
COMPLIANCE SAMPLE: YES	REPLACEMENT SAMPLE: NO
SAMPLE TYPE:	
PWS #:	PWS NAME: PENDLETON SCHOOL DISTRICT
CONTACT NAME: TABLE ROCK ANALYTICAL LAB	CONTACT PHONE:



Anatek Labs, Inc.

1282 Alturas Drive
Moscow, ID 83843
(208) 883-2839
FAX 882-9246
moscow@anateklabs.com

504 E. Sprague Ste. D
Spokane, WA 99202
(509) 838-3999
FAX 838-4433
spokane@anateklabs.com

www.anateklabs.com

Lead Analysis Report

Lab Sample #	Sample Location	Collection Date / Time	Analyte	Result	Method	Analysis Date	Analyst	Qualifier
160815007-015	160811A15 / MCKAY 18	8/11/2016 6:38 AM	Lead	0.0476	EPA 200.8	8/19/2016	ETL	
160815007-016	160811A16 / MCKAY 19	8/11/2016 6:42 AM	Lead	0.0123	EPA 200.8	8/19/2016	ETL	
160815007-017	160811A17 / MCKAY 20	8/11/2016 6:47 AM	Lead	0.00316	EPA 200.8	8/19/2016	ETL	
160815007-018	160811A18 / MCKAY 21	8/11/2016 6:44 AM	Lead	0.00270	EPA 200.8	8/19/2016	ETL	
160815007-019	160811A19 / MCKAY 22	8/11/2016 6:50 AM	Lead	0.0102	EPA 200.8	8/19/2016	ETL	

MCL (Maximum Contaminant Level) for Lead is 0.020 mg/L.

MDL (Method Detection Limit) is 0.001 mg/L for Lead.

ND = Analyte Not Detected

All results in mg/L unless otherwise noted.


This report shall not be reproduced except in full, without the written approval of the laboratory.

The results reported relate only to the samples indicated.

Soil/solid results are reported on a dry-weight basis unless otherwise noted.

TABLE ROCK ANALYTICAL LAB
PENDLETON SCHOOL DISTRICT
419 SW 5TH STREET
PENDLETON, OR 97801

Authorized Signature


Todd Taruscio, Lab Manager

Comments:

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595
Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

2016-2017 Lead (Water) Testing

Building	Location	Code	Sample ID	Sampled By	Date	Time
McKay	Room 145	Drinking Fountain	McKay 4	Ken Lebsack	8/11/2016	6:16 AM
McKay	Room 143	Drinking Fountain	McKay 5	Ken Lebsack	8/11/2016	6:18 AM
McKay	Outside Primary	Drinking Fountain	McKay 6	Ken Lebsack	8/11/2016	6:21
McKay	Room 136	Drinking Fountain	McKay 7	Ken Lebsack	8/11/2016	6:24 AM
McKay	Room 135	Drinking Fountain	McKay 8	Ken Lebsack	8/11/2016	6:25 AM
McKay	Room 134	Drinking Fountain	McKay 9	Ken Lebsack	8/11/2016	6:26 AM
McKay	Room 133	Drinking Fountain	McKay 10	Ken Lebsack	8/11/2016	6:28 AM
McKay	Room 127	Drinking Fountain	McKay 11	Ken Lebsack	8/11/2016	6:29 AM
McKay	Room 125	Drinking Fountain	McKay 12	Ken Lebsack	8/11/2016	6:31 AM
McKay	Room 124	Drinking Fountain	McKay 13	Ken Lebsack	8/11/2016	6:33
McKay	Room 121	Drinking Fountain	McKay 14	Ken Lebsack	8/11/2016	6:34
McKay	Room 120	Drinking Fountain	McKay 15	Ken Lebsack	8/11/2016	6:35
McKay	Room 113	Drinking Fountain	McKay 16	Ken Lebsack	8/11/2016	6:40
McKay	Room 116	Drinking Fountain	McKay 17	Ken Lebsack	8/11/2016	6:39 AM
McKay	Room 117	Drinking Fountain	McKay 18	Ken Lebsack	8/11/2016	6:38 AM
McKay	Outside Intermediate	Drinking Fountain	McKay 19	Ken Lebsack	8/11/2016	6:42 AM
McKay	Gym 104	Drinking Fountain	McKay 20	Ken Lebsack	8/11/2016	6:47
McKay	Room 171 North	Drinking Fountain/Sink	McKay 21	Ken Lebsack	8/11/2016	6:44 AM
McKay	Room 171 South	Drinking Fountain/Sink	McKay 22	Ken Lebsack	8/11/2016	6:50

2:1
 Samples
 pendleton SD

ANATEK LABS RECEIVING LIST

RECEIVED INTACT
 LABELS & CHAINS AGREE
 NO HEADSPACE
 ICE / ICE-PACKS PRESENT
 CUSTODY SEALS PRESENT

TEMP: 5.3 °C
 THERM# IR-1

PRESERVATIVES: _____

NUMBER OF CONTAINERS: 27.19 SHIPPED VIA: UPS

DATE & TIME: 8/12/16 11:25 INSPECTED BY: JK

→ BUR 8/11/16 1610

KCC 8/11/16 0910 BUR