

Executive Summary Facilities Committee Meeting

DATE: June 10, 2025

TOPIC: Replacement of Lincoln Hall Flooring, Classrooms 300 and 303

PREPARED BY: Jim Caldwell

Recommended for:

□ Discussion

Purpose/Background:

After the Lincoln Hall construction in 2018, two classrooms experienced carpet tiles coming up causing tripping hazards. It was found that the carpet tiles were installed over LVT flooring. The Administration is recommending removing faulty carpet tiles, coating the LVT flooring with concrete patch, and replacing with new carpet tiles.

Fiscal Impact:

Classroom 300 - Carpet Tile, Base, Prep and Demo, \$7605

Classroom 303 - Carpet Tile, Base, Prep and Demo, \$7425

Recommendation:

The Facilities Committee concurs with the Administration's recommendation to the Board of Education to approve this Agreement from Johnson Floor Company, Inc. for the Carpet Tile, Base, Prep and Demo For classroom 300 and 303 in an amount not to exceed \$15,100.