

# Memo

**To:** Board of Education  
**From:** David Nardone  
**CC:** Dr. Conway  
**Date:** 3/9/2017  
**Re:** Property Update

---

The following is an update on our school buildings:

## **Bradley**

A heat pipe burst and was repaired.

A heat controller failed - one wing was without heat and the replacement part was ordered.

## **Irving**

Adjustments were made to the heating systems in many classrooms to optimize comfort.

The main sewer line was clogged and needed to be cleared.

## **Derby High School**

Outlets and lighting were installed in the woodshop.

Repairs made in bathrooms.

## **Derby Middle School**

A vent stack was damaged by the wind and was repaired.

Intake vents were sealed to stop a leak in the gym.

Respectfully submitted by,

David M. Nardone, Facilities Manager