

FACILITIES/CONSTRUCTION REPORT

JUNE 2021

BMS Renovation/Addition:

6-23 Sunny, warm. Vemco diagnose and make changes to new chiller, 1 worker. Hagestad sanding new doors for paint, 1 worker.

6-24 Sunny, warm. Hagestad sanding new doors for paint, 1 worker.

6-29 Sunny, hot. Wadworth adjust pressure switches for the (2) automatic glycol feed tanks for the chiller and the boilers, refill the glycol tanks to full, 1 worker.