




## GENERAL NOTES

1. REFER TO SHEET E1.1 FOR GENERAL ELECTRICAL NOTES THAT SHALL APPLY TO ALL SHEETS IN THIS SET UNLESS NOTED OTHERWISE IN THE KEYED NOTES.

## KEYNOTE LEGEND

- 1 DURING PORTABLE RELOCATION, PANEL WAS DISLOADED FROM THE WALL. REAFFIX PANEL AND REPAIR ANY DAMAGED TERMINATIONS, FUSES, AND BREAKERS.
- 2 ROUTE UNDERGROUND CONDUIT FROM DISCONNECT SWITCHES TO PORTABLE BUILDINGS. CONTRACTOR SHALL PROVIDE EXACT TIE-INS WITH THE EXISTING SITE CONDITIONS PRIOR TO INSTALLATION.
- 3 NEW RACK, REF: DETAIL 2L1-E.13
- 4 NEW PCE POLE-MOUNTED TRANSFORMER
- 5 EXISTING PCE POLE-MOUNTED TRANSFORMER
- 6 EXISTING PCE POLE-MOUNTED TRANSFORMERS: (2) SERVICE DROPS OFF ONE POLE.
- 7 EXISTING SERVICE FOR EXISTING MAIN BUILDING AND SERVICE FOR (3) EXISTING PORTABLES.
- 8 NEW RACK, REF: SHEET L-E-8.1 PROVIDE METER AND (3) 2P/200A/FNEMA 3R FUSED DISCONNECT SWITCHES TO SERVE PORTABLE BUILDINGS HP23, HP28, AND HP46.
- 9 NEW RACK, REF: SHEET L-E-8.1 PROVIDE METER AND (2) 2P/200A/FNEMA 3R FUSED DISCONNECT SWITCHES TO SERVE PORTABLE BUILDINGS HP33 AND HP42.
- 10 EXISTING SERVICE CONDUCTORS DOWNSTREAM OF THE METER ARE CURRENTLY UNDERSIZED AT 200-AMPS. REPLACE CONDUCTORS WITH 800A, 2 SETS OF 4-600 KCMIL, 1/0G AND REPLACE GUTTER TO ACCOMMODATE UPSIZING.

### LINETYPE LEGEND

-  EXISTING UNDERGROUND POWER  
 EXISTING OVERHEAD POWER  
 NEW UNDERGROUND POWER  
 NEW OVERHEAD POWER  
 PEC 20-FT ELECTRIC EASEMENT

1 ELECTRIC EASEMENTS REFERENCE PLAN - EXHIBIT 'A'

SCALE: 1/16" = 1'-0"

