

# Grand Prairie ISD Board of Trustees

CREATE.  
EMPOWER.  
LEAD.


Information

Action

Consent

**Topic:** HVAC at Grand Prairie High School Tower

**Submitted by:** Joel Falcon, Chief of Operations

**Approved for Transmittal:** 

**Board Meeting Date:** 12/12/2024

**Recommendation:**

The Administration will update the Board of Trustees on HVAC at the Grand Prairie High School Tower; a timeline will be included.

**Rationale:**

The existing VRF HVAC system is problematic throughout the entire building. A third-party engineering firm has recommended that the HVAC system be replaced with a water-source heat pump HVAC system.

**Budget Information:**

General Fund

**Board Policy Reference and Compliance:**

CH(LOCAL)  
CH(LEGAL)