

1920



School Radon Testing Report

David Lake
April 22, 2021

School Radon Testing Report

District 191 School Board Report on Radon Testing April 22, 2021

- Per MN Statute 123B.571 subd. 3, a school district that has tested its school buildings for the presence of radon shall report the results of its tests to the Department of Health and report results to the school board.
- Field Environmental Consulting, Inc. was authorized by David Lake, Director of Operations, to conduct short-term radon monitoring at the following sites:
 - **Gideon Pond, Vista View, Harriet Bishop, Edward Neill, Rahn and William Byrne**
- Radon levels are measured in picocuries per liter or pCi/L. EPA and MDH action level for indoor radon is 4.0 pCi/L.
- Six sites/schools were included in this radon project and 371 samples were retrieved and analyzed. (GP-46, VV-44, HB-67, EN-70, WB-76, Rn-68) [2021 Radon Report--6 Sites.pdf](#)
- All remaining sites/schools will be tested after Nov. 1, per MDH recommendations
- **Summary: no radon levels above the action level of ≥ 4.0 pCi/L were identified for any locations at these schools.**

Thank You