



Dalton Refrigeration
Truck #2 TRUSTY STEED
6320 Quinhagak St.
ANCHORAGE, AK 99507
(907) 240-4440

Sales Order 862765

SALESPERSON Guy Peterson
guy@drefrigeration.com
WORK ORDER 1544829

SHIP TO

North Slope Borough School District
(907) 852-9763

BILL TO (#1149040)

North Slope Borough School District
(907) 852-9763

CUST PO

CONTACT Jill Crooks Jill.Crooks@nsbsd.org (907) 852-9763

SHIP OUT Will Call

DROP SHIP No

#	PART	DESCRIPTION	QTY	B/O	FILLED	RATE	DISC	NET	EXT
	Machine	Work #1544829 performed on Multiple Machines: Hours: 0			1.00				0.00
	NOTE	WAINWRIGHT 8/18-8/19			1.00				0.00
1	JOB	(DRF) 8/19 UNIT INSPECTIONS	0.00			0.00		0.00	0.00
	COMPLAINT	8/19 UNIT INSPECTIONS FREEZERS DOWN							
	CAUSE	DEFROST TERMINATION FAN DELAY FAILURE ON THE SOUTH SIDE UNIT NORTH SIDE UNIT NEEDS TO BE REPLACED.							
	CORRECTION	REMOVED DTF SWITCH FROM NORTH UNIT AND REPLACED THE ONES ON SOUTH UNIT WAS ABLE TO GET SOUTH UNIT UP AND RUNNING.							
2	OUT OF TOWN - DAILY RATE	(DRF) Labor for 8/18 - 8/19 UNIT INSPECTIONS WAINWRIGHT	2.00		2.00	2,300.00		2,300.00	4,600.00

PAYMENT	DETAILS	DATE	AMT

COMMENTS

SUBTOTAL	4,600.00
TOTAL	4,600.00
PAYMENTS	0.00
BALANCE DUE	4,600.00

ACCEPTANCE: _____ **DATE:** _____

Thank you for your Business