



SOUTH SAN ANTONIO INDEPENDENT SCHOOL DISTRICT

Agenda Item Summary

Meeting Date: December 18<sup>th</sup>, 2019

Purpose:  Presentation/Report  Recognition  Discussion/ Possible Action

Closed/Executive Session  Work Session  Discussion Only  Consent

From: Connie Prado, Board President

Item Title: Presentation by Garza Bomberger on Olivares complex Status Report

Description:

Historical Data:

Recommendation: Report Only

District Goal/Strategy:

Strategy 1 We will engage all school community members through transparency and effective communication to promote a positive perception and create a strong brand.

Funding Budget Code and Amount:

APPROVED BY:

SIGNATURE

DATE

Chief Officer:

*Handwritten signature of Chief Officer*

*12/12/19*

CFO Funding Approval:

\_\_\_\_\_

\_\_\_\_\_

Superintendent:

\_\_\_\_\_

\_\_\_\_\_

SOUTH SAN I.S.D.



OLIVARES CAMPUS RENOVATION



# ADA NON COMPLIANCE REPORT



## FIRE MARSHALL ITEMS TO BE APPROVED FOR COMPLIANCE

- 1.-APPROVE EXISTING PANIC HARDWARE AT DOORS.
- 2.- ALL EXISTING DOORS W/VISION PANEL- WIRE GLASS NO LONGER COMPLIES WITH CURRENT CODE..

## COURTESY INSPECTION BY RAS INSPECTOR AND GBA

- 3.- HANDRAIL IS REQUIRED AT STEPS & RAMP.
- 4.- SPACE ON BACK STAGE DOES NOT COMPLY.
- 5.- DOORS NEED TO BE RELOCATED TO COMPLY WITH 18" CLEAR APPROCH.
- 6.- HEIGHT AND LOCATION OF FIXTURES AND ACCESSORIES AT RESTROOMS NEED TO BE ADJUSTED
- 7.- REMOVE EXISTING DOOR.
- 8.- TURN INTO A SINGLE USE TOILET.


# ADA NON COMPLIANCE REPORT

## FIRE MARSHALL ITEMS TO BE APPROVED FOR COMPLIANCE

- 1.-APPROVE EXISTING PANIC HARDWARE AT DOORS.
- 2.- ALL EXISTING DOORS W/VISION PANEL- WIRE GLASS NO LONGER COMPLIES WITH CURRENT CODE..

## COURTESY INSPECTION BY RAS INSPECTOR AND GBA

- 3.- HANDRAIL IS REQUIRED AT STEPS & RAMP.
- 4.- SPACE ON BACK STAGE DOES NOT COMPLY.
- 5.- DOORS NEED TO BE RELOCATED TO COMPLY WITH 18" CLEAR APPROCH.
- 6.- HEIGHT AND LOCATION OF FIXTURES AND ACCESSORIES AT RESTROOMS NEED TO BE ADJUSTED
- 7.- REMOVE EXISTING DOOR.
- 8.- TURN INTO A SINGLE USE TOILET.



1ST FLOOR  
NTS

