

FACILITIES/CONSTRUCTION REPORT
JANUARY 2025

Napi Kitchen flooring:

- 1-1 Calm, cool@46 degrees. Pierce Flooring install new flooring, welds not holding. 4 workers.
- 1-2 Calm, cool@40 degrees. Pierce Flooring install new flooring, new welds were brought up and used, install metal trim on cove base, caulk, 3 workers.