## Facilities Work Progress Report for **New Berlin Elementary**

## Board Report for November 2022

Sould report to the terminal 2022		
w.l.a.	2	
Work to Begin or in Progress	Description	Update
S&W sidewalk project complete		
mounted boxes on outside entry for quick emergency responder access		
repair GEO leak in 312	actuator valve leaking, repaired	
Had Geo leak on a 6" line repaired on Tuesdat Nov 8th	had to bleed system, replace a section of T's	leak repaired
worked thru short staffing for a few weeks, [1 resignation and sickness]		Have full staff now
mini split heat pump in server room quit again, room 95*. In Process of replacing outdated unit	new units different voltage, had to have wire ran	
Started replacing filters on air handelers, heat pumps		
Have snow equipment ready for winter		
replaced faucet in kitchen to be hands free per Health Dept regulations		complete
installed umbrellas in KG Playground that were purchased with pre-k funds		complete
replaced light ballast in 5 classrooms		