

Memo

To: Board of Education
From: David Nardone
CC: Dr. Conway
Date: 11/9/2016
Re: Property Update

Following is a highlight of the past month:

Bradley

Installation of four (4) security cameras is underway.

Four (4) roof top fans were repaired.

Measurements for the window replacement were taken in preparation for the RFQ

Irving

Installation of four (4) security cameras was started.

Fire alarm system was repaired.

Reviewing quotes from the stair replacement RFQ.

Derby High School

LRU playground is 90% complete.

Seven (7) doors have been repaired to self-close and lock.

Derby Middle School

A failed flange on a heat line was repaired.

Bearings on a roof top unit failed.

Respectfully submitted by,

David M. Nardone, Facilities Manager