# **Facilities, DPS**

# Memo

To: Board of Education

From: David Nardone

**CC:** Dr. Conway **Date:** 6/13/2018

Re: Property Update

The following is an update on our school buildings:

# **Bradley**

The power supply for the fire alarm panel failed and was replaced.

A roof ventilation fan in the gym failed and was repaired.

#### **Irving**

A duct smoke detector burned out in the kitchen and was replaced by an outside contractor.

Summer maintenance was performed on roof top units.

# **Derby High School**

Several roof leaks have been repaired.

Obtaining price to repair leaking skylight.

Auditorium seating installation completed.

# **Derby Middle School**

The energy management system which controls the heating, cooling and lighting of the building stopped functioning and was repaired.

A compressor on the chiller failed; obtaining prices to repair.

Respectfully submitted by,

David M. Nardone, Facilities Manager