

**From:** Kevin DePottey <[kdepottey@gcdcwws.com](mailto:kdepottey@gcdcwws.com)>

**Sent:** 07 April 2025 10:36

**To:** Joseph Rizk <[jrizk@viennatwpgc.gov](mailto:jrizk@viennatwpgc.gov)>; Michelle Falardeau <[mfalardeau@viennatwpgc.gov](mailto:mfalardeau@viennatwpgc.gov)>; Ken Kalakay <[kkalakay@gcdcwws.com](mailto:kkalakay@gcdcwws.com)>

**Cc:** Pat McNamara <[pmcnamara@gcdcwws.com](mailto:pmcnamara@gcdcwws.com)>

**Subject:** RE: Dutchman's Pump Station

That is difficult to answer. We can't predict when a pump will fail. One pump can handle the flow for that station. For the price I recommend replacing instead of repairing. We can keep the station operational until the pump arrives. We have connections and probably can get the pump a little quicker.

Kevin M. DePottey  
Sewer Superintendent  
Genesee County Drain Commissioners Office  
Division of Water and Waste Services  
G-4610 Beecher Road  
Flint, Michigan 48532  
Office 810-732-7870 ext 4153

**From:** Joseph Rizk <[jrizk@viennatwpgc.gov](mailto:jrizk@viennatwpgc.gov)>

**Sent:** Monday, April 7, 2025 7:14 AM

**To:** Kevin DePottey <[kdepottey@gcdcwws.com](mailto:kdepottey@gcdcwws.com)>; Michelle Falardeau <[mfalardeau@viennatwpgc.gov](mailto:mfalardeau@viennatwpgc.gov)>; Ken Kalakay <[kkalakay@gcdcwws.com](mailto:kkalakay@gcdcwws.com)>

**Cc:** Pat McNamara <[pmcnamara@gcdcwws.com](mailto:pmcnamara@gcdcwws.com)>

**Subject:** RE: Dutchman's Pump Station

Thanks for the update.

I had asked the question on the phone about the sense of urgency and you responded that the pump that is running the show is capable of lasting until the new one is in. I believe I misunderstood on the lead time for the new pump. Do you still feel we are in good shape to last as long until 4 months is up?

**From:** Kevin DePottey <[kdepottey@gcdcwws.com](mailto:kdepottey@gcdcwws.com)>

**Sent:** 03 April 2025 15:34

**To:** Michelle Falardeau <[mfalardeau@viennatwpgc.gov](mailto:mfalardeau@viennatwpgc.gov)>; Joseph Rizk <[jrizk@viennatwpgc.gov](mailto:jrizk@viennatwpgc.gov)>; Ken Kalakay <[kkalakay@gcdcwws.com](mailto:kkalakay@gcdcwws.com)>

**Cc:** Pat McNamara <[pmcnamara@gcdcwws.com](mailto:pmcnamara@gcdcwws.com)>

**Subject:** RE: Dutchman's Pump Station

Please see attached quotes. If you have any questions please let me know.

Kevin M. DePottey  
Sewer Superintendent  
Genesee County Drain Commissioners Office  
Division of Water and Waste Services  
G-4610 Beecher Road  
Flint, Michigan 48532  
Office 810-732-7870 ext 4153

**From:** Michelle Falardeau <[mfalardeau@viennatwpgc.gov](mailto:mfalardeau@viennatwpgc.gov)>  
**Sent:** Thursday, April 3, 2025 9:39 AM  
**To:** Kevin DePottey <[kdepottey@gcdcwws.com](mailto:kdepottey@gcdcwws.com)>; Joseph Rizk <[jrizk@viennatwpgc.gov](mailto:jrizk@viennatwpgc.gov)>; Ken Kalakay <[kkalakay@gcdcwws.com](mailto:kkalakay@gcdcwws.com)>  
**Cc:** Pat McNamara <[pmcnamara@gcdcwws.com](mailto:pmcnamara@gcdcwws.com)>  
**Subject:** RE: Dutchman's Pump Station

Also, can you please tell us if this is pump 1 or 2?

Thanks,

*Michelle Falardeau*

**Accountant**

**3400 W. Vienna Road, Clio, MI 48420**

**Direct Phone: 810-564-7075 | Direct Fax: 810-564-7074**



**From:** Kevin DePottey <[kdepottey@gcdcwws.com](mailto:kdepottey@gcdcwws.com)>  
**Sent:** Thursday, April 3, 2025 8:49 AM  
**To:** Joseph Rizk <[jrizk@viennatwpgc.gov](mailto:jrizk@viennatwpgc.gov)>; Ken Kalakay <[kkalakay@gcdcwws.com](mailto:kkalakay@gcdcwws.com)>  
**Cc:** Pat McNamara <[pmcnamara@gcdcwws.com](mailto:pmcnamara@gcdcwws.com)>; Michelle Falardeau <[mfalardeau@viennatwpgc.gov](mailto:mfalardeau@viennatwpgc.gov)>  
**Subject:** RE: Dutchman's Pump Station

The cost for the replacement is \$11,000 plus our mark up. The repair was \$8250 plus mark up.

Kevin M. DePottey  
Sewer Superintendent  
Genesee County Drain Commissioners Office  
Division of Water and Waste Services  
G-4610 Beecher Road  
Flint, Michigan 48532  
Office 810-732-7870 ext 4153

**From:** Joseph Rizk <[jrizk@viennatwpgc.gov](mailto:jrizk@viennatwpgc.gov)>  
**Sent:** Thursday, April 3, 2025 8:38 AM  
**To:** Ken Kalakay <[kkalakay@gcdcwws.com](mailto:kkalakay@gcdcwws.com)>; Kevin DePottey <[kdepottey@gcdcwws.com](mailto:kdepottey@gcdcwws.com)>

**Cc:** Pat McNamara <[pmcnamara@gcdcwws.com](mailto:pmcnamara@gcdcwws.com)>; Michelle Falardeau <[mfalardeau@viennatwpgc.gov](mailto:mfalardeau@viennatwpgc.gov)>  
**Subject:** RE: Dutchman's Pump Station

I do not see a cost for replacement

**From:** Ken Kalakay <[kkalakay@gcdcwws.com](mailto:kkalakay@gcdcwws.com)>  
**Sent:** 01 April 2025 14:02  
**To:** Kevin DePottey <[kdepottey@gcdcwws.com](mailto:kdepottey@gcdcwws.com)>; Joseph Rizk <[jrizk@viennatwpgc.gov](mailto:jrizk@viennatwpgc.gov)>  
**Cc:** Pat McNamara <[pmcnamara@gcdcwws.com](mailto:pmcnamara@gcdcwws.com)>  
**Subject:** RE: Dutchman's Pump Station

Hi Joe here is the quotes for repairs on pump. Please let me know if you would like repair or replace the pump. Please let me know so I can let Kennedy know.  
Thanks Ken

**From:** Kevin DePottey <[kdepottey@gcdcwws.com](mailto:kdepottey@gcdcwws.com)>  
**Sent:** Wednesday, March 19, 2025 1:07 PM  
**To:** [jrizk@viennatwpgc.gov](mailto:jrizk@viennatwpgc.gov)  
**Cc:** Pat McNamara <[pmcnamara@gcdcwws.com](mailto:pmcnamara@gcdcwws.com)>; Ken Kalakay <[kkalakay@gcdcwws.com](mailto:kkalakay@gcdcwws.com)>  
**Subject:** Dutchman's Pump Station

Joe

Our crew went out on a call at the abovementioned station and found a pump has failed. We are going to pull the pump and send it in for repair. As soon as we have a price for the repair I will get that sent over to you.

Kevin M. DePottey  
Sewer Superintendent  
Genesee County Drain Commissioners Office  
Division of Water and Waste Services  
G-4610 Beecher Road  
Flint, Michigan 48532  
Office 810-732-7870 ext 4153