

NRPP 105011 AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

Absolute Environmental
4615 NE Shaver Street
Portland OR 97213

Sheridan School District 448J
435 S Bridge Street
Sheridan OR 97378


Log Number	Device Number	Test Exposure Duration:		Area Tested	Result pCi/L
3307755	4149781	03/23/2020 8:36 am	03/27/2020 5:10 am	Gymnasium First Floor <i>H.S old</i>	1.4
3307756	4149782	03/23/2020 8:36 am	03/27/2020 5:11 am	Gymnasium First Floor <i>H.S old</i>	1.3
3307757	4149783	03/23/2020 8:36 am	03/27/2020 5:12 am	Gymnasium First Floor <i>H.S old</i>	1.2
3307758	4149784	03/23/2020 8:36 am	03/27/2020 5:13 am	Gymnasium First Floor <i>H.S old</i>	1.3
3307759	4149785	03/23/2020 8:33 am	03/27/2020 5:14 am	Room 19 First Floor <i>H.S.</i>	2.2
3307760	4149786	03/23/2020 8:30 am	03/27/2020 5:15 am	Cafeteria First Floor <i>H.S.</i>	1.4
3307761	4149787	03/23/2020 8:30 am	03/27/2020 5:16 am	Cafeteria First Floor <i>H.S.</i>	0.9
3307762	4149788	03/23/2020 8:28 am	03/27/2020 5:17 am	Office First Floor <i>H.S.</i>	0.5
3307763	4149789	03/23/2020 8:26 am	03/27/2020 5:18 am	Room 1 First Floor <i>H.S.</i>	0.7
3307764	4149790	03/23/2020 8:25 am	03/27/2020 5:19 am	Room 2 First Floor <i>H.S.</i>	< 0.4
3307765	4149771	03/23/2020 9:57 am	03/27/2020 5:11 am	Room 113 <i>Fcs</i>	< 0.4

Comment: AMENDED REPORT on 4-6-20 to add corrected stop times.

Test Performed By: Mike Stipan

Distributed by: Absolute Environmental

Date Received: 03/31/2020 Date Logged: 03/31/2020 Date Analyzed: 03/31/2020 Date Reported: 04/01/2020

Report Reviewed By: 

Report Approved By: 

Disclaimer:

The uncertainty of this radon measurement is +/- 10%. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

Shawn Price, Director of Laboratory Operations, AccuStar Labs

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NRPP 105011 AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

Absolute Environmental
4615 NE Shaver Street
Portland OR 97213

Sheridan School District 448J
435 S Bridge Street
Sheridan OR 97378


Log Number	Device Number	Test Exposure Duration:		Area Tested	Result pCi/L
3307766	4149772	03/23/2020 9:55 am	03/27/2020 5:12 am	Room 112 <i>Fcs</i>	< 0.4
3307767	4149773	03/23/2020 9:53 am	03/27/2020 5:13 am	Room 110 <i>Fcs</i>	< 0.4
3307768	4149774	03/23/2020 9:53 am	03/27/2020 5:14 am	Room 110 Duplicate <i>Fcs</i>	< 0.4
3307769	4149775	03/23/2020 9:51 am	03/27/2020 5:15 am	Room 109 <i>Fcs</i>	< 0.4
3307770	4149776	03/23/2020 9:50 am	03/27/2020 5:16 am	Room 108 <i>Fcs</i>	< 0.4
3307771	4149777	03/23/2020 9:49 am	03/27/2020 5:17 am	Room 107 <i>Fcs</i>	< 0.4
3307772	4149778	03/23/2020 9:48 am	03/27/2020 5:18 am	Library <i>Fcs</i>	0.8
3307773	4149779	03/23/2020 9:48 am	03/27/2020 5:19 am	Library <i>Fcs</i>	0.6
3307774	4149780	03/23/2020 9:47 am	03/27/2020 5:20 am	Room 106 <i>Fcs</i>	< 0.4
3307775	4159211	03/23/2020 9:45 am	03/27/2020 5:21 am	Room 105 First Floor <i>Fcs</i>	< 0.4
3307776	4159212	03/23/2020 9:44 am	03/27/2020 5:22 am	Room 104 First Floor <i>Fcs</i>	< 0.4

Comment: AMENDED REPORT on 4-6-20 to add corrected stop times.

Test Performed By: Mike Stipan

Distributed by: Absolute Environmental

Date Received: 03/31/2020 Date Logged: 03/31/2020 Date Analyzed: 03/31/2020 Date Reported: 04/01/2020

Report Reviewed By: 

Report Approved By: 

Disclaimer:

The uncertainty of this radon measurement is ~+/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

Shawn Price, Director of Laboratory Operations, AccuStar Labs

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NRPP 105011 AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

Absolute Environmental
4615 NE Shaver Street
Portland OR 97213

Sheridan School District 448J
435 S Bridge Street
Sheridan OR 97378


Log Number	Device Number	Test Exposure	Duration:	Area Tested	Result pCi/L
3307777	4159213	03/23/2020 9:43 am	03/27/2020 5:23 am	Room 103 First Floor <i>Fcs</i>	< 0.4
3307778	4159214	03/23/2020 9:36 am	03/27/2020 5:24 am	Gymnasium Field Blank First Floor <i>Fcs</i>	< 0.4
3307779	4159215	03/23/2020 9:36 am	03/27/2020 5:25 am	Gymnasium Duplicate First Floor <i>Fcs</i>	< 0.4
3307780	4159216	03/23/2020 9:37 am	03/27/2020 5:26 am	Gymnasium First Floor <i>Fcs</i>	< 0.4
3307781	4159217	03/23/2020 9:37 am	03/27/2020 5:27 am	Gymnasium First Floor <i>Fcs</i>	< 0.4
3307782	4159218	03/23/2020 9:38 am	03/27/2020 5:28 am	Gymnasium First Floor <i>Fcs</i>	< 0.4
3307783	4159219	03/23/2020 9:38 am	03/27/2020 5:29 am	Gymnasium First Floor <i>Fcs</i>	< 0.4
3307784	4159220	03/23/2020 9:36 am	03/27/2020 5:30 am	Cafeteria First Floor <i>Fcs</i>	< 0.4
3307785	4159221	03/23/2020 9:02 am	03/27/2020 5:01 am	Staff Room First Floor <i>Fcs</i>	0.8
3307786	4159222	03/23/2020 8:59 am	03/27/2020 5:02 am	Room Kitchen First Floor <i>Fcs</i>	1.5
3307787	4159223	03/23/2020 8:52 am	03/27/2020 5:03 am	Work Room Field Blank First Floor <i>Fcs</i>	< 0.4

Comment: AMENDED REPORT on 4-6-20 to add corrected stop times.

Test Performed By: Mike Stipan

Distributed by: Absolute Environmental

Date Received: 03/31/2020 Date Logged: 03/31/2020 Date Analyzed: 03/31/2020 Date Reported: 04/01/2020

Report Reviewed By: 

Report Approved By: 
Shawn Price, Director of Laboratory Operations, AccuStar Labs

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NRPP 105011 AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

Absolute Environmental
4615 NE Shaver Street
Portland OR 97213

Sheridan School District 448J
435 S Bridge Street
Sheridan OR 97378


Log Number	Device Number	Test Exposure Duration:	Area Tested	Result pCi/L
3307788	4159224	03/23/2020 8:48 am 03/27/2020 5:04 am	Shop First Floor <i>H.S</i>	1.1
3307789	4159225	03/23/2020 8:52 am 03/27/2020 5:05 am	Work Room First Floor <i>H.S</i>	1.1
3307790	4159226	03/23/2020 8:45 am 03/27/2020 5:06 am	Library First Floor <i>H.S</i>	< 0.4
3307791	4159227	03/23/2020 8:45 am 03/27/2020 5:07 am	Library First Floor Duplicate <i>H.S</i>	< 0.4
3307792	4149848	03/23/2020 8:47 am 03/27/2020 5:08 am	Room 18 First Floor <i>H.S</i>	0.6
3307793	4149849	03/23/2020 8:43 am 03/27/2020 5:09 am	Gym First Floor Duplicate <i>H.S. old</i>	0.9
3307794	4149850	03/23/2020 8:43 am 03/27/2020 5:10 am	Gym First Floor Field Blank <i>H.S. old</i>	< 0.4
3307795	4149751	03/23/2020 9:36 am 03/27/2020 5:10 am	Cafeteria First Floor <i>H.S</i>	< 0.4
3307796	4149752	03/23/2020 9:32 am 03/27/2020 5:11 am	Kitchen First Floor <i>H.S</i>	< 0.4
3307797	4149753	03/23/2020 9:30 am 03/27/2020 5:12 am	Room 125 First Floor <i>Fcs</i>	< 0.4
3307798	4149754	03/23/2020 9:27 am 03/27/2020 5:13 am	Room 126 First Floor <i>Fcs</i>	< 0.4

Comment: AMENDED REPORT on 4-6-20 to add corrected stop times.

Test Performed By: Mike Stipan

Distributed by: Absolute Environmental

Date Received: 03/31/2020 Date Logged: 03/31/2020 Date Analyzed: 03/31/2020 Date Reported: 04/01/2020

Report Reviewed By: 

Report Approved By: 

Disclaimer:

The uncertainty of this radon measurement is +/- 10%. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

Shawn Price, Director of Laboratory Operations, AccuStar Labs

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NRPP 105011 AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

Absolute Environmental
4615 NE Shaver Street
Portland OR 97213

Sheridan School District 448J
435 S Bridge Street
Sheridan OR 97378

Log Number	Device Number	Test Exposure Duration:	Area Tested	Result pCi/L
3307799	4149755	03/23/2020 9:28 am 03/27/2020 5:14 am	Room 124 First Floor <i>FCS</i>	< 0.4
3307800	4149756	03/23/2020 9:27 am 03/27/2020 5:15 am	Room 123 First Floor <i>FCS</i>	< 0.4
3307801	4149757	03/23/2020 9:06 am 03/27/2020 5:16 am	New Gymnasium First Floor <i>μS</i>	< 0.4
3307802	4149758	03/23/2020 9:06 am 03/27/2020 5:17 am	New Gymnasium First Floor <i>μS</i>	< 0.4
3307803	4149759	03/23/2020 9:06 am 03/27/2020 5:18 am	New Gymnasium First Floor <i>μS</i>	< 0.4
3307804	4149760	03/23/2020 9:06 am 03/27/2020 5:19 am	New Gymnasium First Floor <i>μS</i>	< 0.4
3307805	4149761	03/23/2020 10:14 am 03/27/2020 6:01 am	Room 122 First Floor <i>FCS</i>	< 0.4
3307806	4149762	03/23/2020 10:13 am 03/27/2020 6:02 am	Room 121 First Floor <i>FCS</i>	< 0.4
3307807	4149763	03/23/2020 10:13 am 03/27/2020 6:03 am	Room 120 First Floor <i>FCS</i>	< 0.4
3307808	4149764	03/23/2020 10:11 am 03/27/2020 6:04 am	Room 119 First Floor <i>FCS</i>	< 0.4
3307809	4149765	03/23/2020 10:09 am 03/27/2020 6:05 am	Room 118 First Floor Field Blank <i>FCS</i>	< 0.4

Comment: AMENDED REPORT on 4-6-20 to add corrected stop times.

Test Performed By: Mike Stipan

Distributed by: Absolute Environmental

Date Received: 03/31/2020 Date Logged: 03/31/2020 Date Analyzed: 03/31/2020 Date Reported: 04/01/2020

Report Reviewed By: *Jeffrey Kardon*

Report Approved By: *Shawn Price*

Disclaimer:

The uncertainty of this radon measurement is ~+/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NRPP 105011 AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

Absolute Environmental
4615 NE Shaver Street
Portland OR 97213

Sheridan School District 448J
435 S Bridge Street
Sheridan OR 97378


Log Number	Device Number	Test Exposure	Duration:	Area Tested	Result pCi/L
3307810	4149766	03/23/2020 10:04 am	03/27/2020 6:06 am	Room 118 First Floor <i>FCS</i>	< 0.4
3307811	4149767	03/23/2020 10:07 am	03/27/2020 6:07 am	Room 117 First Floor <i>FCS</i>	< 0.4
3307812	4149768	03/23/2020 10:00 am	03/27/2020 6:08 am	Room 116 First Floor <i>FCS</i>	0.4
3307813	4149769	03/23/2020 10:03 am	03/27/2020 6:09 am	Room 115 First Floor <i>FCS</i>	< 0.4
3307814	4149770	03/23/2020 10:01 am	03/27/2020 6:10 am	Room 114 First Floor <i>FCS</i>	0.5
3307815	4149791	03/23/2020 8:06 am	03/27/2020 5:00 am	Room 14 First Floor <i>H. S.</i>	1.3
3307816	4149792	03/23/2020 8:08 am	03/27/2020 5:01 am	Room 13 First Floor <i>H. S.</i>	< 0.4
3307817	4149793	03/23/2020 8:12 am	03/27/2020 5:02 am	Room 12 First Floor <i>H. S.</i>	< 0.4
3307818	4149794	03/23/2020 8:16 am	03/27/2020 5:03 am	Custodian First Floor <i>H. S.</i>	1.5
3307819	4149795	03/23/2020 8:18 am	03/27/2020 5:04 am	Room 8 First Floor <i>H. S.</i>	2.0
3307820	4149796	03/23/2020 8:19 am	03/27/2020 5:05 am	Room 7 First Floor <i>H. S.</i>	2.9


Comment: AMENDED REPORT on 4-6-20 to add corrected stop times.

Test Performed By: Mike Stipan

Distributed by: Absolute Environmental

Date Received: 03/31/2020 Date Logged: 03/31/2020 Date Analyzed: 03/31/2020 Date Reported: 04/01/2020

Report Reviewed By: 

Report Approved By: 

Disclaimer:

The uncertainty of this radon measurement is +/- 10%. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

Shawn Price, Director of Laboratory Operations, AccuStar Labs

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NRPP 105011 AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

Absolute Environmental
4615 NE Shaver Street
Portland OR 97213

Sheridan School District 448J
435 S Bridge Street
Sheridan OR 97378


Log Number	Device Number	Test Exposure Duration:	Area Tested	Result pCi/L
3307821	4149797	03/23/2020 8:20 am 03/27/2020 5:06 am	Room 6 First Floor <i>Fcs H.S.</i>	< 0.4
3307822	4149798	03/23/2020 8:21 am 03/27/2020 5:07 am	Room 5 First Floor <i>Fcs H.S.</i>	< 0.4
3307823	4149799	03/23/2020 8:22 am 03/27/2020 5:08 am	Room 4 First Floor <i>Fcs H.S.</i>	< 0.4
3307824	4149800	03/23/2020 8:23 am 03/27/2020 5:09 am	Room 3 First Floor <i>H.S.</i>	< 0.4
3307825	4159201	03/23/2020 10:42 am 03/27/2020 6:10 am	District Office Board Room First Floor	0.7
3307826	4159202	03/23/2020 10:42 am 03/27/2020 6:11 am	District Office Fiscal Office First Floor	< 0.4
3307827	4159203	03/23/2020 11:05 am 03/27/2020 6:12 am	Raser First Floor <i>H.S.</i>	0.8
3307828	4159204	03/23/2020 10:19 am 03/27/2020 6:13 am	Music First Floor <i>Fcs</i>	0.6
3307829	4159205	03/23/2020 10:19 am 03/27/2020 6:14 am	Old Gymnasium First Floor <i>Fcs</i>	0.5
3307830	4159206	03/23/2020 10:19 am 03/27/2020 6:15 am	Old Gymnasium First Floor <i>Fcs</i>	< 0.4
3307831	4159207	03/23/2020 10:19 am 03/27/2020 6:16 am	Old Gymnasium First Floor <i>Fcs</i>	< 0.4


Comment: AMENDED REPORT on 4-6-20 to add corrected stop times.

Test Performed By: Mike Stipan

Distributed by: Absolute Environmental

Date Received: 03/31/2020 Date Logged: 03/31/2020 Date Analyzed: 03/31/2020 Date Reported: 04/01/2020

Report Reviewed By: 

Report Approved By: 

Disclaimer:

The uncertainty of this radon measurement is +/- 10%. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

Shawn Price, Director of Laboratory Operations, AccuStar Labs

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.

NRPP 105011 AL
NRSB ARL0007

EPA Method #402-R-92-004
Charcoal Canister
NRPP Device Code 6048
NRSB Device Code 10317

Laboratory Report for:

Property Tested:

Absolute Environmental
4615 NE Shaver Street
Portland OR 97213

Sheridan School District 448J
435 S Bridge Street
Sheridan OR 97378


Log Number	Device Number	Test Exposure Duration:	Area Tested	Result pCi/L
3307832	4159208	03/23/2020 10:19 am 03/27/2020 6:17 am	Old Gymnasium First Floor <i>FCS</i>	0.5
3307833	4159209	03/23/2020 10:16 am 03/27/2020 6:18 am	Room 101 First Floor <i>FCS</i>	< 0.4
3307834	4159210	03/23/2020 10:14 am 03/27/2020 6:19 am	Office First Floor <i>FCS</i>	< 0.4

Comment: AMENDED REPORT on 4-6-20 to add corrected stop times.

Test Performed By: Mike Stipan

Distributed by: Absolute Environmental

Date Received: 03/31/2020 Date Logged: 03/31/2020 Date Analyzed: 03/31/2020 Date Reported: 04/01/2020

Report Reviewed By: 

Report Approved By: 

Disclaimer:

The uncertainty of this radon measurement is +/- 10 %. Factors contributing to uncertainty include statistical variations, daily and seasonal variations in radon concentrations, sample collection techniques and operation of the dwelling. Interference with test conditions may influence the test results.

Shawn Price, Director of Laboratory Operations, AccuStar Labs

This report may only be transferred to a third party in its entirety. Analytical results relate to the samples AS RECEIVED BY THE LABORATORY. Results shown on this report represent levels of radon gas measured between the dates shown in the room or area of the site identified above as "Property Tested". Incorrect information will affect results. The results may not be construed as either predictive or supportive of measurements conducted in any area of this structure at any other time. AccuStar Labs, its employees and agents are not responsible for the consequences of any action taken or not taken based upon the results reported or any verbal or written interpretation of the results.