

MAINTENANCE REPORT SEPTEMBER 2023

Submitted by: Reid Reagan

Maintenance staff has been busy assisting with the decorating for Homecoming activities, also preventive maintenance on the heating systems, cleaning strainers, replacing air filters. Groundskeepers have been painting Napi football field, also winterizing sprinkler systems, blowing out water sprinkler systems with air to prevent freezing and remove all pumps/tanks. Responded to 92 work orders, all repairs or service calls.

BHS:

Replace (1) more new water booster pump, total of (3), retrofit from old to new piping.

BMS:

Haul in new storage shed with roll-up door and rot resistant floor, used to store trash. Install new door fob reader for the kitchen door.

BES:

Install new door fob reader for Parent Community Outreach Program, also repair/replace 2" heat supply line which has been leaking under the school.

Bus Garage:

Run new power supply for new underground fuel storage tank monitoring system.

NAPI:

Install (2) new boiler pumps, retrofit from old to new piping.

BABB:

Repair areas of asphalt roof leaking.