

MAINTENANCE REPORT

November 15, 2016

SUBMITTED BY: Richard Sanchez

The maintenance department set up for the diabetes screening at Napi and BMS.

Our locksmith re-cored 28 cores at the new Vo-Tech Building.

Titan Machinery came and serviced both our skidster and loader. The loader looked like it may need some work on the rear end as it's only in two wheel so we took it to Shelby to get repaired.

We had to replace 3 exhaust fan motors at BES and replaced a blower motor in room 210.

We Completed putting up wrestling pads on walls in wrestling room.

I took the state boiler inspector to Napi, BES, and BHS to get state ID numbers and other info off new boilers that were recently installed.

We re-spread woodchips in all playgrounds where needed.

Since last report the maintenance staff has completed numerous work order requests and responded to numerous trouble calls. We are still picking up trash on the fence lines and grounds daily.