

**COIT**  
CLEANING & RESTORATION



11100 Hampshire Avenue S.  
Bloomington, MN 55438  
612-716-2029


## CERTIFICATE OF FLAME RESISTANCE

This is to certify that the materials described herein have been flame retardant treated or are inherently flame resistant.

**For :** Badger Independent School District # 676  
**Address :** 110 Carpenter Avenue  
**City:** Badger **State:** MN **Zip Code:** 56714  
**Invoice Number:** 880607 **Date of Application:** January 15, 2024  
**Item:** Stage Drapery **Fabric Content:** Velour Cotton Blend

### CERTIFICATION IS HEREBY MADE THAT:

- (A) The articles above have been treated with an approved flame-retardant chemical incorporating the provisions of the National Fire Protection Code (NFPA) # 701. Chemical used is: Burn Barrier FPR — Class A ASTM E-84 Rated.
- (B) The articles described above were previously treated with a flame-retardant chemical. Field testing has proven that cleaning has not rendered the treatment ineffective according to the field testing requirements of the National Fire Protection Code.
- (C) The articles described above are made from an inherently flame-resistant fabric or material.
- (D) The Flame Retardant Treatment will NOT be removed by washing.



January 15, 2029  
EXPIRATION DATE

Signature

Date

1-15-2024