



Executive Summary Board of Education Meeting

DATE: June 26, 2025

TOPIC: Remove Pipe Tee to Prevent Nurse Toilet Room Backup

PREPARED BY: Jim Caldwell

Recommended for:

- ☒ Action
- ☒ Discussion
- ☒ Information

Purpose/Background:

Summer 2023 nurses office at Todd Hall was remodeled. After we have experienced the water closet drainline frequently backup into the nurses washroom. After camera and inspecting the drain line we found a pipe tee under the hallway holding debris. The Administration recommends breaking up the concrete floor and replacing the tee with 45% pipe to resolve the issue.

Fiscal Impact:

Little Tommy's Plumbing \$3,730 in budget year 2025-2026

Johnson Floors \$3,480 in budget year 2025-2026

Recommendation:

The Facilities Committee concurred with the Administration's recommendation to the Board of Education to approve the Proposal for Little Tommy's Plumbing shop, Inc. for \$3,730, and the Proposal for Johnson Flooring Company, Inc. not to exceed \$3,480.