

# Lead Testing

Sheridan School District

# Lead Testing Results

Date	Site	Results mg/liter	EPA School mg/liter
6/22/2016	SHS – Drinking Fountain Front Entry	ND @ 0.001	0.020
6/22/2016	SHS - Kitchen	0.0048	0.020
6/22/2016	SHS – Drinking Fountain New Gym Lobby	ND @ 0.001	0.020
6/22/2016	SHS – Drinking Fountain East Side of New Gym	ND @ 0.001	0.020
6/22/2016	FC -Kitchen	0.0082	0.020
6/22/2016	FC – Front Hall Drinking Fountain	ND @ 0.001	0.020
6/22/2016	FC – Old Gym Boys Locker Room	0.0113	0.020
6/22/2016	FC - Band Room Sink	0.0234	0.020
6/22/2016	FC – Up Stairs Drinking Fountain	ND @ 0.001	0.020
6/22/2016	TA - Kitchen	0.0041	0.020
6/22/2016	House of Hope	0.0021	0.020
6/22/2016	DO - Kitchen	0.0090	0.020

# Lead Testing Mitigation Plan

- The old Gym at Faulconer-Chapman was the only location that tested above the limit.
- We will have drinking water unavailable in the old gym until we have a solution and retested the water
- Possible solutions include replacing fixtures and/or adding filters to the system



Thank You