

Grand Prairie ISD Board of Trustees

CREATE.
EMPOWER.
LEAD.

Information

Action

Consent

Topic: Replacement of Underground Fuel System Tanks at Gentry Long Service Center

Submitted by: Joel Falcon, Chief of Operations

Approved for Transmittal:

Board Meeting Date: 3/13/2025

Recommendation:

It is recommended that the Board of Trustees approve the underground storage tank project through RFP #24-08 with Covey Brothers Contracting in the amount of \$1,139,261.98.

Rationale:

The four underground storage tanks (USTs) currently in use at Gentry Long range in age from 27 to 30 years. The life expectancy of USTs is typically 30 years. Due to the nature of the construction, it is recommended that the work be done in two phases. New fuel dispensers, fuel lines, and electrical systems will be included in the installation of the new USTs.

Budget Information:

Mackenzie Scott Donation

Board Policy Reference and Compliance:

CH (LOCAL)
CH (LEGAL)