

Grand Prairie ISD Board of Trustees

CREATE.
EMPOWER.
LEAD.

Information

Action

Consent

Topic: Engineering/Design Services or Fees for Grand Prairie High School Tower and Grand Prairie Fine Arts

Submitted by: Joel Falcon, Chief of Operations

Approved for Transmittal: 

Board Meeting Date: 11/14/2024

Recommendation:

It is recommended that the Board of Trustees approve the engineering/design services or fees for the following:

Grand Prairie High School Tower - Mechanical, electrical, plumbing (MEP) and structural engineering design services to replace the existing VRF HVAC system in the amount of \$500,000.

Grand Prairie Fine Arts Academy - Mechanical, electrical, plumbing (MEP) and structural engineering design services for both gymnasiums' HVAC replacement in the amount of \$50,000.

Rationale:

Grand Prairie High School Tower – The existing VRF HVAC system is problematic throughout the entire building. A third-party engineering firm has recommended that the HVAC system be replaced.

Grand Prairie Fine Arts Academy – The existing geothermal system that provides heating and cooling for both gymnasiums has developed water leaks within the wells. A third-party engineering firm has recommended that the existing geothermal system be replaced with four new rooftop units (RTUs).

Budget Information:

Fund Balance

Board Policy Reference and Compliance:

CH(LEGAL)

CH(LOCAL)