

LAB FEDERAL ID#: ID00013	
DATE RECEIVED: 8/16/2016	DATE REPORTED BY LAB: 8/26/2016
COMPLIANCE SAMPLE: YES	REPLACEMENT SAMPLE: NO
SAMPLE TYPE:	
PWS #:	PWS NAME: PENDLETON SCHOOL DISTRICT
CONTACT NAME: TABLE ROCK ANALYTICAL LAB	CONTACT PHONE:



Anatek Labs, Inc.

1282 Alturas Drive
Moscow, ID 83843
(208) 883-2839
FAX 882-9246
moscow@anateklabs.com

504 E. Sprague Ste. D
Spokane, WA 99202
(509) 838-3999
FAX 838-4433
spokane@anateklabs.com

www.anateklabs.com

Lead Analysis Report

Lab Sample #	Sample Location	Collection Date / Time	Analyte	Result	Method	Analysis Date	Analyst	Qualifier
160817027-001	160812D1 / PHS 12	8/12/2016 1:12 PM	Lead	0.0112	EPA 200.8	8/24/2016	ETL	
160817027-002	160812D2 / PHS 13	8/12/2016 1:18 PM	Lead	ND	EPA 200.8	8/24/2016	ETL	
160817027-003	160812D3 / PHS 14	8/12/2016 1:14 PM	Lead	0.00175	EPA 200.8	8/24/2016	ETL	
160817027-004	160812D4 / PHS 15	8/12/2016 1:14 PM	Lead	0.00876	EPA 200.8	8/24/2016	ETL	
160817027-005	160812D5 / PHS 16	8/12/2016 1:14 PM	Lead	0.00262	EPA 200.8	8/24/2016	ETL	
160817027-006	160812D6 / PHS 17	8/12/2016 1:14 PM	Lead	0.00580	EPA 200.8	8/24/2016	ETL	
160817027-007	160812D7 / PHS 18	8/12/2016 1:15 PM	Lead	0.00253	EPA 200.8	8/24/2016	ETL	
160817027-008	160812D8 / PHS 19	8/12/2016 1:23 PM	Lead	0.00946	EPA 200.8	8/24/2016	ETL	
160817027-009	160812D9 / PHS 20	8/12/2016 1:21 PM	Lead	0.00229	EPA 200.8	8/24/2016	ETL	
160817027-010	160812D10 / PHS 21	8/12/2016 2:00 PM	Lead	0.00204	EPA 200.8	8/24/2016	ETL	
160817027-011	160812D11 / PHS 22	8/12/2016 2:00 PM	Lead	0.00162	EPA 200.8	8/24/2016	ETL	
160817027-012	160812D12 / PHS 23	8/12/2016 2:00 PM	Lead	0.00318	EPA 200.8	8/24/2016	ETL	
160817027-013	160812D13 / PHS 24	8/12/2016 1:25 PM	Lead	ND	EPA 200.8	8/24/2016	ETL	
160817027-014	160812D14 / PHS 25	8/12/2016 1:27 PM	Lead	ND	EPA 200.8	8/24/2016	ETL	
160817027-015	160812D15 / PHS 26	8/12/2016 1:28 PM	Lead	ND	EPA 200.8	8/24/2016	ETL	
160817027-016	160812D16 / PHS 27	8/12/2016 1:46 PM	Lead	0.00176	EPA 200.8	8/24/2016	ETL	
160817027-017	160812D17 / PHS 28	8/12/2016 1:45 PM	Lead	ND	EPA 200.8	8/24/2016	ETL	
160817027-018	160812D18 / PHS 29	8/12/2016 1:39 PM	Lead	0.00268	EPA 200.8	8/24/2016	ETL	
160817027-019	160812D19 / PHS 30	8/12/2016 1:37 PM	Lead	0.00370	EPA 200.8	8/24/2016	ETL	

Comments: PENDLETON HIGH SCHOOL

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595
 Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

LAB FEDERAL ID#:		ID00013	
DATE RECEIVED:		DATE REPORTED BY LAB:	
8/16/2016		8/26/2016	
COMPLIANCE SAMPLE:	YES	REPLACEMENT SAMPLE:	NO
SAMPLE TYPE:			
PWS #:	PWS NAME:		
	PENDLETON SCHOOL DISTRICT		
CONTACT NAME:		CONTACT PHONE:	
TABLE ROCK ANALYTICAL LAB			



Anatek Labs, Inc.

1282 Alturas Drive
Moscow, ID 83843
(208) 883-2839
FAX 882-9246
moscow@anateklabs.com

504 E. Sprague Ste. D
Spokane, WA 99202
(509) 838-3999
FAX 838-4433
spokane@anateklabs.com

www.anateklabs.com

Lead Analysis Report

Lab Sample #	Sample Location	Collection Date / Time	Analyte	Result	Method	Analysis Date	Analyst	Qualifier
160817027-020	160812D20 / PHS 31	8/12/2016 1:39 PM	Lead	ND	EPA 200.8	8/24/2016	ETL	
160817027-021	160812D21 / PHS 32	8/12/2016 2:04 PM	Lead	0.00384	EPA 200.8	8/24/2016	ETL	
160817027-022	160812D22 / PHS 33	8/12/2016 2:05 PM	Lead	0.00123	EPA 200.8	8/24/2016	ETL	
160817027-023	160812D23 / PHS 34	8/12/2016 1:57 PM	Lead	0.00190	EPA 200.8	8/24/2016	ETL	
160817027-024	160812D24 / PHS 35	8/12/2016 1:57 PM	Lead	0.00199	EPA 200.8	8/24/2016	ETL	
160817027-025	160812D25 / PHS 36	8/12/2016 1:54 PM	Lead	0.00140	EPA 200.8	8/24/2016	ETL	
160817027-026	160812D26 / PHS 37	8/12/2016 1:50 PM	Lead	0.00102	EPA 200.8	8/24/2016	ETL	
160817027-027	160812D27 / PHS 38	8/12/2016 1:52 PM	Lead	0.00108	EPA 200.8	8/24/2016	ETL	
160817027-028	160812D28 / PHS 39	8/12/2016 2:09 PM	Lead	0.0345	EPA 200.8	8/24/2016	ETL	
160817027-029	160812D29 / PHS 40	8/12/2016 2:09 PM	Lead	0.0282	EPA 200.8	8/24/2016	ETL	
160817027-030	160812D30 / PHS 41	8/12/2016 2:19 PM	Lead	0.0161	EPA 200.8	8/24/2016	ETL	
160817027-031	160812D31 / PHS 42	8/12/2016 2:25 PM	Lead	ND	EPA 200.8	8/24/2016	ETL	
160817027-032	160812D32 / PHS 43	8/12/2016 2:25 PM	Lead	ND	EPA 200.8	8/24/2016	ETL	
160817027-033	160812D33 / PHS 44	8/12/2016 2:25 PM	Lead	0.00258	EPA 200.8	8/24/2016	ETL	
160817027-034	160812D34 / PHS 45	8/12/2016 2:25 PM	Lead	0.00509	EPA 200.8	8/24/2016	ETL	
160817027-035	160812D35 / PHS 46	8/12/2016 2:25 PM	Lead	0.0118	EPA 200.8	8/24/2016	ETL	
160817027-036	160812D36 / PHS 47	8/12/2016 2:21 PM	Lead	ND	EPA 200.8	8/24/2016	ETL	
160817027-037	160812D37 / PHS 48	8/12/2016 2:22 PM	Lead	ND	EPA 200.8	8/24/2016	ETL	
160817027-038	160812D38 / PHS 49	8/12/2016 2:30 PM	Lead	0.00169	EPA 200.8	8/24/2016	ETL	

Comments: PENDLETON HIGH SCHOOL

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595
 Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

LAB FEDERAL ID#: ID00013	
DATE RECEIVED: 8/16/2016	DATE REPORTED BY LAB: 8/26/2016
COMPLIANCE SAMPLE: YES	REPLACEMENT SAMPLE: NO
SAMPLE TYPE:	
PWS #:	PWS NAME: PENDLETON SCHOOL DISTRICT
CONTACT NAME: TABLE ROCK ANALYTICAL LAB	CONTACT PHONE:



Anatek Labs, Inc.

1282 Alturas Drive
 Moscow, ID 83843
 (208) 883-2839
 FAX 882-9246
 moscow@anateklabs.com

504 E. Sprague Ste. D
 Spokane, WA 99202
 (509) 838-3999
 FAX 838-4433
 spokane@anateklabs.com

www.anateklabs.com

Lead Analysis Report

Lab Sample #	Sample Location	Collection Date / Time	Analyte	Result	Method	Analysis Date	Analyst	Qualifier
160817027-039	160812D39 / PHS 50	8/12/2016 2:16 PM	Lead	ND	EPA 200.8	8/24/2016	ETL	

MCL (Maximum Contaminant Level) for Lead is 0.020 mg/L.

MDL (Method Detection Limit) is 0.001 mg/L for Lead.

ND = Analyte Not Detected

All results in mg/L unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The results reported relate only to the samples indicated.

Soil/solid results are reported on a dry-weight basis unless otherwise noted.

TABLE ROCK ANALYTICAL LAB
 PENDLETON SCHOOL DISTRICT
 419 SW 5TH STREET
 PENDLETON, OR 97801

Authorized Signature


 Todd Taruscio, Lab Manager

Comments: PENDLETON HIGH SCHOOL

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595
 Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

Pendleton SD

160817 027 PESD Last Dup 8/26/2016
 1st SAMP 8/12/2016 1st RCVD 8/16/2016
 :PHS

160812D

2016-2017 Lead (Water) Testing

Building	Location	Code	Sample ID	Sampled By	Date	Time
PHS	Room 217B	HS Infant Sink	PHS 12 D1	Ken Lebock	8/12/2016	1:12 PM
PHS	First Floor	Drinking Fountain	PHS 13 D2	Ken Lebock	8/12/2016	1:14 PM
PHS	Room 221	Sink 2	PHS 14 D3	Ken Lebock	8/12/2016	1:14 PM
PHS	Room 221	Sink 3	PHS 15 D4	Ken Lebock	8/12/2016	1:14 PM
PHS	Room 221	Sink 4	PHS 16 D5	Ken Lebock	8/12/2016	1:14 PM
PHS	Room 221	Sink 5	PHS 17 D6	Ken Lebock	8/12/2016	1:14 PM
PHS	Room 221	Sink 6	PHS 18 D7	Ken Lebock	8/12/2016	1:14 PM
PHS	Room 210	Sink	PHS 19 D8	Ken Lebock	8/12/2016	1:23 AM
PHS	Room 208	Sink	PHS 20 D9	Ken Lebock	8/12/2016	1:21 PM
PHS	Bld 4 Greenhouse	Sink	PHS 21 D10	Ken Lebock	8/12/2016	2:00 PM
PHS	Bld 4 Room 103	Sink	PHS 22 D11	Ken Lebock	8/12/2016	2:00 PM
PHS	Bld 4 Room 108	Sink	PHS 23 D12	Ken Lebock	8/12/2016	2:00 PM
PHS	Staff Room 302	Sink	PHS 24 D13	Ken Lebock	8/12/2016	2:00 PM
PHS	Office	Drinking Fountain	PHS 25 D14	Ken Lebock	8/12/2016	1:25 PM
PHS	Health Room (Office)	Sink	PHS 26 D15	Ken Lebock	8/12/2016	1:27 AM
PHS	Warberg Training Room	Sink	PHS 27 D16	Ken Lebock	8/12/2016	1:28 PM
PHS	Warberg Gym	Drinking Fountain 2	PHS 28 D17	Ken Lebock	8/12/2016	1:45 PM
PHS	Room 536	Sink	PHS 29 D18	Ken Lebock	8/12/2016	1:40 PM
PHS	Student Store	Sink	PHS 30 D19	Ken Lebock	8/12/2016	1:39 PM
PHS	Room 520A	Sink	PHS 31 D20	Ken Lebock	8/12/2016	1:37 AM
PHS	Journalism Room	Sink	PHS 32 D21	Ken Lebock	8/12/2016	1:39 AM
PHS	Conference Room	Sink	PHS 33 D22	Ken Lebock	8/12/2016	2:05 PM
PHS	Room 905	Sink	PHS 34 D23	Ken Lebock	8/12/2016	2:05 PM
PHS	Room 904	Sink	PHS 35 D24	Ken Lebock	8/12/2016	1:57 AM
PHS	Room 907	Sink	PHS 36 D25	Ken Lebock	8/12/2016	1:57 PM
PHS	Room 936	Sink	PHS 37 D26	Ken Lebock	8/12/2016	1:54 AM
PHS	Room 940	Sink	PHS 38 D27	Ken Lebock	8/12/2016	1:50 AM
PHS	Gold Gym Girls Dressing Room	Sink 1	PHS 39 D28	Ken Lebock	8/12/2016	1:52 PM
PHS	Gold Gym Girls Dressing Room	Sink 2	PHS 40 D29	Ken Lebock	8/12/2016	2:09 PM
PHS	Band Room 1225	Sink	PHS 41 D30	Ken Lebock	8/12/2016	2:09 PM
PHS	Art Room 1201	Sink 1	PHS 42 D31	Ken Lebock	8/12/2016	2:19 PM
PHS	Art Room 1201	Sink 2	PHS 43 D32	Ken Lebock	8/12/2016	2:25 PM

1:18 TD:

TDF

1:46

1:45

2:04

MWB

recd 8/12/16 BUR

