

# RADON TESTING RESULTS

Sheridan School Board April 2020

- ▶ 4.0 or higher pCi/L requires mitigation
- ▶ No results above 2.9 pCi/L
- ▶ Results will be posted on the website

## RADON TESTING RESULTS

THANK YOU

