

Rwd 9-11-23  
UB  
No 0611



# Ed Perrault Plumbing

Master Plumber  
(989) 733-0075

6765 E. County Rd. 638 Hwy., Posen, MI 49776

## Contractors Invoice

TO: County of Alpena 720 W Chisholm St Suite 7 Alpena MI 49707		WORK PERFORMED AT: Sunken Lake Park
DATE: 9/8/23	YOUR WORK ORDER NO.	OUR BID NO.

### DESCRIPTION OF WORK PERFORMED

4/29/23

1.) Meet with Ma Duffy To Show Him New-procedure To Return water service to New Bath Area Also to New Large Double TANK water Softener System. & water test softener & Piping which could not be ck'd when installed Due to CAN NOT TEST with Air. System installed in winter months & MANUFACTURER SAYS "Do Not Test with Air. Fill system ck for leaks (1) was located & REPAIRED Also time. TUNE & set parameters on computer Boards. REPLACE water Hester Filter & Return water to tank;

Thank you  
😊  
EP

\* I DID NOT Tell Marty Thompson That I Included Extra Hester Springs Time Start up 9/8/23.

All Material is guaranteed to be as specified, and the above work was performed in accordance with the drawings and specifications provided for the above work and was completed in a substantial workmanlike manner for the agreed sum of \$855.00

Dollars (\$ 855.00)

This is a  Partial  Full invoice due and payable by: \_\_\_\_\_

Month

Day

Year