

Memo

To: Board of Education
From: David Nardone
CC: Dr. Conway
Date: 6/21/2021
Re: Property Update

Following is a highlight of the work we have done in the past month:

Bradley

Hallways and classrooms were cleaned during the April shutdown. Main sewer line clogged

Irving

Hallways and classrooms were cleaned during the April shutdown the hot water heater failed and was replaced.

Derby High School

Hallways and classrooms were cleaned during the April shutdown.

Derby Middle School

The fire alarm system was tested A main entrance door was rehung. Rooftop units had filters changed chiller was started. A tower water line broke a braded fitting failed.

Respectfully submitted by,

David M. Nardone, Facilities Manager