RETEROCES: Proving = 8.5_11 Tribblocking _Std Did SDAS
Oct 26, 2022 = 12.31pm _C/_SP\/Provingnoc Engineering\/Projects = 0.courserts\/Active Projects\/002.22.01 377 EST\/6. Drawings\/Appendix 0 = Logo Specifications.deg _LVYOUT: Layor1 _USD1:



EXISTING TANK & LOGO

40-feet -

STEPHENV





NEW TANK LOGO DESIGN

TANK DETAILS:

ADDRESS: OWNER: TANK CAPACITY: 377 ELEVATED STORAGE TANK 536 COUNTY ROAD 386 CITY OF STEPHENVILLE

BEBAS NEUE - BOLD

TANK DIMENSIONS:

APPROX. OVERALL HEIGHT: 96' - 0" TALL TCL: BCL 93' - 0" 53' - 0" TANK DIAMETER: 55' - 10' 40' - 0"

NEW LOGO COLORS:

BLUE #191577 (CANVA) YELLOW/GOLD #FFC61E (CANVA)

NEW LOGO FONTS:

STEPHENVILLE: CITY OF CHAMPIONS:

BARLOW SEMICONDENSED - BOLD & ITALICS HONEYBEES & YELLOW JACKETS: BARLOW SEMICONDENSED - BOLD

NEW LOGO PRODUCTS:

AS SPECIFIED IN SECTION 43 01 40.16 - REHABILITATION OF EXISTING TANK.

NOTES:

- DIGITAL FILE MAY BE AVAILABLE UPON REQUEST TO CONTRACTOR.
- DIMENSIONS SHOWN IN THE FIGURE ABOVE ARE ESTIMATES PROVIDED FOR BIDDING PURPOSES. CONTRACTOR SHALL FIELD VERIFY OVERALL DIMENSIONS OF EXISTING LOGO PRIOR TO ITS REMOVAL, OVERALL DIMENSIONS OF NEW LOGO ARE NOT PROPORTIONATE TO EXISTING LOGO. CONTRACTOR SHALL MATCH THE OVERALL HEIGHT OF THE NEW
- LOGO TO THAT OF THE EXISTING LOGO. SUBMITTAL WITH FIELD DIMENSIONS OF EXISTING LOGO AND PROPOSED DIMENSIONS OF NEW LOGO TO BE REVIEWED AND APPROVED BY ENGINEER PRIOR TO INSTALLATION.

DATE:	OCT. 2022
CHECKED BY:	K RIKER
DESIGNED BY:	F. SAMFORD
DRAWN BY:	T. MODDY
PROJECT LD.	002.22.01

В

SHEET TITLE:

TANK LOGO DETAILS

PROJECT TITLE:

CITY OF STEPHENVILLE, TEXAS 377 EST REHABILITATION



298 W Weshington St., Stephenville, TX 78401 254-918-1220 - www.stephenvillets.gov



D49 Edwards Ranch Rd., Ste. 400, Fot Worth, TX 76 817-785-7171 - www.proyensyssensiness

THESE DOCUMENTS ARE ISSUED FOR INTERIM REMEW ONLY AND ARE NOT INTENDED FOR CONSTRUCTION, SIDDING, OR PERMIT PURPOSES

6.	Furnish all materials, equipment, labor, superintendence and incidental work to perform epoxy surfacing, installing Tnemec Series 215 product at areas deemed necessary in accordance with the Technical Specifications Part 3.01.A.2, except where specifically covered by other bid items.	1	Gallon	\$1,500	\$1,500
7.	Furnish all materials, equipment, labor, superintendence and incidental work to perform seam sealing, installing Sika-Flex 1A or equal NSF approved caulking product at areas deemed necessary in accordance with Technical Specifications Part 3.02.A.2, except where specifically covered by other bid items.	10	Tube	\$50	\$500
8.	Furnish all materials, equipment, labor, superintendence and incidental work for the <u>installation of the Owner logo</u> on tank exterior as indicated in the Technical Specifications Part 2.04.A.	1	LS		\$30,000
Alter	nate Bid Items				
9.	Furnish all materials, equipment, labor, superintendence and incidental work for the <u>complete cleaning</u> , <u>spot</u> repairs, <u>and overcoating</u> of the tank interior dry surfaces as indicated in the Technical Specifications Part 2.04.C.	1	LS		\$15,000

TOTAL BID PRICE FOR BASE BID ITEMS (ITEMS 1 THROUGH 8)

\$ Two Hundred Sixty-Nine Thousand Five Hundred Dollars and Zero Cents 269,500 (in writing)

TOTAL BID PRICE FOR BASE BID AND ALTERNATE ITEMS (ITEMS 1 THROUGH 9)

\$ Two Hundred Eighty-Four Thousand Five Hundred Dollars and Zero Cents

\$_284,500

(In writing) (In our lit is definitely understood that in case of a conflict among the prices quoted for any item in the Bid Form on the foregoing pages, the unit price shall govern.

Time is of the essence. The undersigned bidder agrees to begin work within fourteen (14) calendar days following a written Notice to Proceed to be and substantially complete within 120 calendar days following the start time; provided, however, that the OWNER'S construction funds are available.

Enclosed with this Bid is a Bidder's Bond or Cashier's Check for 5% of total bid including alternates.

(\$_____) dollars, which it is agreed shall be collected and retained by the OWNER as liquidated damages if the OWNER accepts this bid within sixty (60) days after the opening of bids, and the undersigned bidder then fails to execute the contract and bonds with the said OWNER within ten (10) days after official notice of such acceptance; otherwise, said Bidder's Bond or Check shall be returned to the undersigned on demand. This sum of money is not to be considered as a penalty, but shall be deemed, taken and treated as reasonable liquidated damages. The sum of money is fixed and agreed on between the bidder and owner because of the impracticability and extreme difficulty of fixing and ascertaining the actual damage to the OWNER.