




METAL STUD PARTITIONS




CHASE AND FURRING PARTITIONS




MASONRY PARTITIONS (RATED PARTITIONS: UL ASSEMBLY U-906)




FIRE RATED METAL STUD PARTITIONS (RATED PARTITIONS: UL ASSEMBLY U-419)



METAL STUD PARTITIONS - SOUND RATED



LOW WALLS



PARTITION TYPE NUMBERING SYSTEM	
S: STUD	C: CHASE/FURRING
M: MASONRY	R: FIRE-RATED STUD
L: LOW	
S4F.1 S: STANDARD (FULL-HEIGHT STUD, GYPSUM BOARD 6" ABOVE CEILING) F: STUD AND GYPSUM BOARD FULL HEIGHT C: STUD AND GYPSUM BOARD 6" ABOVE CEILING R: SERIES 1: 1 HOUR RATED PARTITION 2: 2 HOUR RATED PARTITION 1: 7/8" FURRING CHANNEL 2: 1 5/8" METAL STUD 3: 2 1/2" METAL STUD 4: 3 5/8" METAL STUD 6: 6" METAL STUD 8: 8" METAL STUD M: SERIES 4: 4" CMU 6: 6" CMU 8: 8" CMU	

PARTITION NOTES	
1.	PROVIDE MOLD AND MOISTURE RESISTANT GYPSUM BOARD FULL HEIGHT ON ALL PARTITIONS UNLESS NOTED OTHERWISE.
2.	FOR ALL FIRE RATED PARTITIONS, PROVIDE FIRE RATED MOLD AND MOISTURE RESISTANT GYPSUM BOARD FULL HEIGHT UNLESS NOTED OTHERWISE.
3.	AT ALL EXISTING RATED WALLS, SEAL ALL NEW AND EXISTING PENETRATIONS WITH UL ASSEMBLIES.
4.	ALL GYPSUM BOARD SHALL BE HELD UP TO 3/8" ABOVE FINISH FLOOR - CAULK BOTTOM (FIRE CAULK AT RATED PARTITIONS).
5.	SEAL HEAD OF WALL CONDITIONS AT ALL EXISTING AND NEW RATED WALLS WITH UL ASSEMBLIES - TYPICAL BOTH SIDES OF RATED WALL.
6.	LABEL ALL FIRE RATED/SMOKE PARTITIONS ABOVE CEILING LEVEL, BOTH FACES OF WALLS: 1 HR RATED WALL
7.	ALL METAL STUDS AND FRAMING TO BE MINIMUM 20 GAUGE, TYP.



2024 Rutledge Hall General Work

Lincolnwood SD74
6850 E Prairie Road, Lincolnwood, IL 60712

NO	ISSUE	DATE
•	CONSTRUCTION	1.4.24
•		
•		
•		
•		
•		
•		
•		
•		

Partition Types

G2.00

23039


DEMOLITION LEGEND

	WALL PARTITION TO BE REMOVED.
	ITEM TO BE REMOVED
	PORTION OF AREA TO BE REMOVED, OR REMOVED AND REINSTALLED. COORDINATE EXTENTS WITH NEW WORK PLANS AND FIELD CONDITIONS
	DEMOLITION KEY NOTE

- DEMOLITION KEY NOTES**
- TYPICAL TOILET ROOM DEMOLITION: REMOVE EXISTING PLUMBING FIXTURE (TOILET AND URINAL), REMOVE EXISTING TOILET ACCESSORIES INCLUDING BUT NOT LIMITED TO SOAP DISPENSERS, WALL-MOUNTED MIRRORS, PAPER TOWEL DISPENSERS, PARTITIONS AND ASSOCIATED PARTITION DOORS, HAND DRYERS, SANITARY DISPENSERS AND GRAB BARS. REMOVE EXISTING TILE FLOORING - FOR THE PURPOSES OF BIDDING, ASSUME ALL CERAMIC TILE FLOORING IS MUD SET AND REMOVE ALL ASSOCIATED MUD SET 2" THICK. INFILL WITH CEMENTITIOUS PRODUCT AS REQUIRED. REPAIR, PREP & LEVEL FLOOR AS NECESSARY TO RECEIVE NEW FLOORING. EXISTING FLOOR DRAIN/LEADOUT TO REMAIN, PROVIDE NEW COVER.
 - REMOVE EXISTING DOOR, FRAME AND ALL ASSOCIATED HARDWARE. SALVAGE HARDWARE AND TURN OVER TO OWNER, CONTRACTOR TO DISPOSE OF ANY HARDWARE NOT WANTED BY OWNER.
 - REMOVE EXISTING FRAME, REMOVE AND SALVAGE EXISTING DOOR AND ALL ASSOCIATED HARDWARE, REINSTALL PER NEW WORK PLANS AND TURN OVER DOOR AND ALL UNUSED HARDWARE TO OWNER.
 - REMOVE EXISTING WALL IN ITS ENTIRETY.
 - REMOVE FLOORING AND RUBBER WALL BASE. REPAIR, PREP & LEVEL FLOOR AS REQUIRED TO RECEIVE NEW FLOOR FINISH.
 - REMOVE WALL COVERING INCLUDING ANY MASTIC OR RESIDUAL MEANS OF ATTACHMENT. TYPICAL ALL WALLS. PREP SURFACES TO RECEIVE NEW WALL FINISH.
 - REMOVE PORTION OF WALL TO EXTENTS SHOWN TO ACCOMMODATE NEW WORK.
 - REMOVE PORTION OF WALL ABOVE CORRIDOR CEILING AS REQUIRED FOR NEW FIRE DAMPER INSTALLATION. PROVIDE NEW STEEL LINTEL AT NEW OPENING.
 - SAWCUT AND REMOVE PORTION OF EXISTING CONCRETE SLAB AS REQUIRED FOR PLUMBING WORK. COORDINATE EXACT LOCATION AND EXTENT OF SLAB REMOVAL IN FIELD AND WITH PLUMBING DRAWINGS.
 - REMOVE EXISTING TILE FLOORING. FOR THE PURPOSES OF BIDDING, ASSUME ALL TILE FLOORING IS MUD SET AND REMOVE ALL ASSOCIATED MUD SET, 2" THICK. INFILL WITH CEMENTITIOUS PRODUCT AS REQUIRED. REPAIR, PREP & LEVEL FLOOR AS NECESSARY TO RECEIVE NEW FLOORING.
 - REMOVE EXISTING CABINET UNIT HEATER AND ALL ASSOCIATED PIPING. PATCH NEWLY EXPOSED WALL TO MATCH EXISTING ADJACENT. COORDINATE EXTENT OF WORK WITH MECHANICAL DRAWINGS.
 - TYPICAL CLASSROOM DEMOLITION: REMOVE EXISTING LAMINATE BASE CABINETS, UPPER CABINETS AND LAMINATE COUNTERTOPS. REMOVE EXISTING BUILT-IN CLOSET CABINETS. REMOVE EXISTING TACKBOARDS, TACK STRIPS, WHITEBOARDS, CHALKBOARDS AND ALL ASSOCIATED TRIM AND MASTIC U.N.O. REMOVE EXISTING FLOOR FINISH AND ALL ASSOCIATED WALL BASE IN ITS ENTIRETY. CAREFULLY REMOVE AND SALVAGE EXISTING MAPS, FILE SLOT AND HAND SANITIZER TO BE REINSTALLED - COORDINATE FINAL LOCATION ON SITE WITH OWNER. EXISTING TECHNOLOGY DISPLAYS TO BE REMOVED BY OWNER.
 - REMOVE EXISTING UNIT VENTILATOR IN ITS ENTIRETY AND ALL ASSOCIATED PIPING/ENCLOSURES/LOUVERS EXCEPT THOSE THAT ARE ENCLOSED BEHIND EXISTING CASEWORK TO REMAIN. PATCH NEWLY EXPOSED WALL TO MATCH EXISTING ADJACENT. COORDINATE EXTENT OF WORK WITH MECHANICAL DRAWINGS.
 - EXISTING CASEWORK TO REMAIN. PROTECT FROM BEING DAMAGED DURING CONSTRUCTION.
 - REMOVE EXISTING DOOR AND ALL ASSOCIATED HARDWARE. EXISTING FRAME TO REMAIN.
 - REMOVE EXISTING FRAME. EXISTING DOOR AND ALL ASSOCIATED HARDWARE TO BE CAREFULLY REMOVED, SALVAGED AND REINSTALLED IN NEW FRAME.
 - EXISTING FRAME TO REMAIN. REMOVE EXISTING DOOR, REMOVE AND SALVAGE ALL EXISTING ASSOCIATED HARDWARE, REINSTALL PER NEW WORK PLANS. TURN OVER ALL UNUSED HARDWARE TO OWNER. CONTRACTOR TO DISPOSE OF ANY HARDWARE NOT WANTED BY OWNER.
 - REMOVE EXISTING WALL LOUVER AND INFILL WALL TO MATCH EXISTING CONSTRUCTION AND THICKNESS.
 - REMOVE EXISTING METAL BASE CABINETS AND ASSOCIATED COUNTERTOP.
 - REMOVE EXISTING GYPSUM FINISH DOWN TO THE EXISTING METAL STUD. EXISTING METAL STUDS TO REMAIN AND RECEIVE NEW GYPSUM BOARD FINISH AFTER NEW WORK IS COMPLETED.
 - REMOVE EXISTING CONVECTOR HEATER AND ALL ASSOCIATED PIPING. PATCH NEWLY EXPOSED WALL TO MATCH EXISTING ADJACENT. COORDINATE EXTENT OF WORK WITH MECHANICAL DRAWINGS.
 - TYPICAL ENTIRE ROOM: EXISTING CEILING SYSTEM AND LIGHT FIXTURES ACCESS PANELS AND DIFFUSERS TO BE REMOVED. TEMPORARILY DISCONNECT, MODIFY AND REINSTALL EXISTING LIFE SAFETY DEVICES TO BE LOCATED IN NEW CEILING. MODIFY DUCTWORK AS REQUIRED. WIRELESS ACCESS POINTS TO BE REMOVED BY OWNER.
 - TEMPORARILY REMOVE EXISTING CEILING SYSTEM. LIGHT FIXTURES AND OTHER CEILING ACCESSORIES AS REQUIRED TO COMPLETE NEW WORK THIS AREA. REINSTALL UPON COMPLETION. REPLACE ANY DAMAGED CEILING TILES.
 - EXISTING TACKBOARDS/TACK STRIPS/WHITEBOARDS/ROLLER SHADES THIS AREA TO REMAIN. PROTECT FROM DAMAGE.
 - REMOVE LOUVER AT FRAME TRANSOM. EXISTING FRAME TO REMAIN. REMOVE ANY UNUSED TRANSOM FASTENERS AND PATCH HOLES.
 - REMOVE EXISTING CEILING GRILLES. SEE MECHANICAL DRAWINGS FOR ADDITIONAL SCOPE. PROVIDE NEW CEILING TILE TO MATCH EXISTING ADJACENT.
 - REMOVE EXISTING SHOWER CURTAIN AND SHOWER FIXTURES AND ACCESSORIES IN THEIR ENTIRETY. CAP PLUMBING AND COORDINATE EXTENT OF WORK WITH PLUMBING DRAWINGS.
 - ALTERNATE #4: REMOVE BULLETIN SURFACE ON BACK OF CLOSET CORRIDOR WALLS AND ALL ASSOCIATED MASTIC AND WOOD PANELING DOWN TO EXISTING PLYWOOD BACKING. PREP TO RECEIVE NEW FINISH. REMOVE TACKBOARDS IN CORRIDOR ABOVE COAT RACKS/HELVES AND ALL ASSOCIATED MASTIC DOWN TO EXISTING WALL. PREP SURFACE TO RECEIVE NEW FINISH.
 - EXISTING SANITARY MAPKIN DISPENSER TO BE CAREFULLY REMOVED, SALVAGED AND REINSTALLED PER NEW WORK PLANS.

- DEMOLITION KEY NOTES**
- TYPICAL ENTIRE ROOM: EXISTING CEILING SYSTEM AND LIGHT FIXTURES ACCESS PANELS AND DIFFUSERS TO BE REMOVED. TEMPORARILY DISCONNECT, MODIFY AND REINSTALL EXISTING LIFE SAFETY DEVICES TO BE LOCATED IN NEW CEILING. MODIFY DUCTWORK AS REQUIRED. WIRELESS ACCESS POINTS TO BE REMOVED BY OWNER.
 - TEMPORARILY REMOVE EXISTING CEILING SYSTEM. LIGHT FIXTURES AND OTHER CEILING ACCESSORIES AS REQUIRED TO COMPLETE NEW WORK THIS AREA. REINSTALL UPON COMPLETION. REPLACE ANY DAMAGED CEILING TILES.
 - EXISTING TACKBOARDS/TACK STRIPS/WHITEBOARDS/ROLLER SHADES THIS AREA TO REMAIN. PROTECT FROM DAMAGE.
 - REMOVE LOUVER AT FRAME TRANSOM. EXISTING FRAME TO REMAIN. REMOVE ANY UNUSED TRANSOM FASTENERS AND PATCH HOLES.
 - REMOVE EXISTING CEILING GRILLES. SEE MECHANICAL DRAWINGS FOR ADDITIONAL SCOPE. PROVIDE NEW CEILING TILE TO MATCH EXISTING ADJACENT.
 - REMOVE EXISTING SHOWER CURTAIN AND SHOWER FIXTURES AND ACCESSORIES IN THEIR ENTIRETY. CAP PLUMBING AND COORDINATE EXTENT OF WORK WITH PLUMBING DRAWINGS.
 - ALTERNATE #4: REMOVE BULLETIN SURFACE ON BACK OF CLOSET CORRIDOR WALLS AND ALL ASSOCIATED MASTIC AND WOOD PANELING DOWN TO EXISTING PLYWOOD BACKING. PREP TO RECEIVE NEW FINISH. REMOVE TACKBOARDS IN CORRIDOR ABOVE COAT RACKS/HELVES AND ALL ASSOCIATED MASTIC DOWN TO EXISTING WALL. PREP SURFACE TO RECEIVE NEW FINISH.
 - EXISTING SANITARY MAPKIN DISPENSER TO BE CAREFULLY REMOVED, SALVAGED AND REINSTALLED PER NEW WORK PLANS.

1 Demolition Plan - Second Floor
1/8" = 1'-0"



2024 Rutledge Hall General Work

Lincolnwood SD74
6850 E Prairie Road, Lincolnwood, IL 60712

NO	ISSUE	DATE
1	CONSTRUCTION CHANGES	1.4.24
.	.	.
.	.	.
.	.	.
.	.	.
.	.	.
.	.	.
.	.	.
.	.	.
.	.	.
.	.	.
.	.	.

**Demolition Plan -
Second Floor**

23039 **AD1.10**

