

IEA, INC.

RUSHFORD-PETERSON SCHOOLS



Contact Us:

BROOKLYN PARK OFFICE

9201 W. BROADWAY, #600
BROOKLYN PARK, MN 55445
763-315-7900

MANKATO OFFICE

610 N. RIVERFRONT DRIVE
MANKATO, MN 56001
507-345-8818

ROCHESTER OFFICE

210 WOOD LAKE DRIVE SE
ROCHESTER, MN 55904
507-281-6664

BRAINERD OFFICE

601 NW 5TH ST. SUITE #4
BRAINERD, MN 56401
218-454-0703

MARSHALL OFFICE

1420 EAST COLLEGE DRIVE
MARSHALL, MN 56258
507-476-3599

VIRGINIA OFFICE

5525 EMERALD AVENUE
MOUNTAIN IRON, MN 55768
218-410-9521

www.ieasafety.com

Info@ieasafety.com

800-233-9513

Management Plan for Lead-in-Water

MAY 15, 2018



Rushford-Peterson Schools
Management Plan for Lead-in-Water

Table of Contents

Annual Review Form

1.0	Purpose.....	1
2.0	Water Sampling Program Development	1
3.0	First Draw Tap Monitoring	1
4.0	Maintenance Procedures	2
5.0	Communication of Results and Follow-up Actions	3
6.0	Recordkeeping	3

Appendices

- A EPA Factsheet: Lead in Drinking Water Coolers
- B Testing Schedule
- C Lead-in-Water Testing Results and Locations
- D Reducing Lead in Drinking Water: Recommended Lead Hazard Reduction Options
- E Parent Notification (Example)

Contact Person: Chuck Ehler, Superintendent

Phone Number: (507) 864-7785

Email Address: chuckehler@r-pschools.com

1.0 Purpose

Rushford-Peterson Schools is committed to providing a safe working and learning environment for employees and students. This Management Plan for Lead-in-Water was developed to reduce the potential for exposure to lead in water and to comply with Minnesota Statute 121A.335, as well as recommendations from the Environmental Protection Agency's (EPA's) *3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance* (2006) and the Lead Contamination Control Act (LCCA) of 1988, the Minnesota Department of Health (MDH) and the Minnesota Department of Education (MDE).

Minnesota Statute 121A.335 requires public school buildings serving kindergarten through grade 12 to test for lead in water in potable water sources (water for consumption) every 5 years. The MDH and MDE have published *Reducing Lead in Drinking Water: A Technical Guidance and Model Plan for Minnesota's Public Schools*, which presents a model plan that school districts can choose to adopt as part of the requirement of Minnesota Statute 121A.335. The *EPA 3Ts* was created by the EPA to identify and reduce lead in drinking water in schools. Lead is a metal that usually enters drinking water through the distribution system, including pipes, solders, faucets, and valves. Lead levels in water may increase when the water is allowed to sit undisturbed in the system. Exposure to lead is a significant health concern.

The *EPA 3Ts* has recommended that schools take remedial action to address lead-in-water exposure whenever lead levels exceed 20 parts per billion (ppb). The MDH and the MDE have jointly provided guidance that there is no safe level of lead and that districts should work to minimize the risk of lead. MDH and MDE recommended actions are described in section 4.0 of this plan.

2.0 Water Sampling Program Development

Identified potable water sources in district facilities, including sinks and drinking fountains in kitchens, staff lounges, classrooms, home economics classrooms, and hallways, will be sampled during the school year throughout the district at least once every five years.

Prior to sampling the following takes place:

- An inventory of potable water taps is taken;
- All drinking fountains are checked to ensure the EPA has not identified them as having a lead lined tank under LCCA. This list can be found in Appendix A.
- Water outlets in restrooms, custodial closets, science labs, art rooms, and other general-purpose workrooms are not included in the sampling inventory, and should be clearly marked not for drinking.

Potable water sources are to be resampled at least once every five years, per MN Statute 121A.335, or when a fixture or water supply is repaired or replaced, or after construction activities that may impact the plumbing system. A testing schedule is included in Appendix B which has each school scheduled to complete testing every 5 years.

3.0 First Draw Tap Monitoring

Water sampling of the identified cold water taps is conducted as a "first draw" sample prior to usage on the day of sampling. Sampling begins at the taps closest to building entry point of water source to prevent accidental flushing of other sample locations in the building. Normal usage of building should occur the day before sampling; sampling should not take place on Mondays or after non-school days.

Taps included in the first draw sampling should not be used for 6-18 hours prior to sampling. If the district cannot ensure identified taps were used the day prior to sampling, flushing will occur according to EPA protocol (2-3 minutes, 8-18 hours prior to sampling). Water samples of 250 milliliters (ml) are analyzed by an accredited testing laboratory, using EPA approved analytical methods and quality control procedures (i.e. such as the ICP/MS EPA Method 200.8).

4.0 Maintenance Procedures

When lead content exceeds 20 ppb, fixtures should be taken out of service until the lead content can be reduced to 20 ppb or lower. While fixtures can still be used for drinking and cooking, MDH and MDE recommend actions be taken to determine the source of lead and reduce lead levels in fixtures when sampling reveals lead content between 2 and 20 ppb. A lead-in-water concentration of or less than 20 ppb (maximum) is considered acceptable by the EPA. Potable water outlets found to have greater than this concentration are repaired, replaced, or flushed.

In addition, the MDH and MDE model plan recommends routine maintenance take place to prevent and help reduce elevated lead levels in drinking water. This includes cleaning faucet aerators where lead-containing materials may accumulate on a quarterly basis and following manufacturer's recommendations for water softener settings to ensure an appropriate level of hardness. The following maintenance procedures are based on MDH/MDE recommended Lead Hazard Reduction Options, located in Appendix D:

Flushing

Flushing may be used as an alternative to repair or replacement. For any location with an elevated lead level, conduct flush sampling to determine if a longer flush will reduce lead levels to an acceptable level. If results indicate that flushing will reduce lead to acceptable levels, implement a flushing program which includes documentation of daily flushing and periodic program review.

Individual Tap Flushing

MDE and MDH suggest running each tap for 2 to 3 minutes in the morning before children arrive, and 2 to 3 minutes midday if the tap has been unused for the morning period. Periodic testing may be done prior to and after the midday flushing to ensure the lead concentrations have remained low throughout the morning hours. If they have not, the flushing time should be increased, or another option implemented.

Main Pipe Flushing

The MDH and MDE model plan explains that Main Pipe Flushing can be used if lead levels are found to be high throughout the entire school or are confined to a certain area of the school. Flushing should be completed each day school is in session. Begin by flushing the tap furthest away from the water source for at least ten minutes; then flush the tap the second furthest away and continue until all taps have been flushed. Periodic testing may be done to ensure the lead concentrations have remained low and that the flushing protocol is effective.

In addition, it is recommended to flush potable water outlets following any two-week vacancy or prior to the beginning of school in the fall, regardless of the lead levels found in the most recent sampling. As long as the fixtures are used regularly, lead levels should remain acceptable. The fixtures should be flushed when the building has been at low occupancy, for example, following school breaks.

Repair and Replace Options

Recommendations of one of the following treatment options for fixtures with lead levels approaching or exceeding the EPA action level may be considered for implementation:

- Install a National Sanitation Foundation (NSF) certified filter for lead reduction.
 - The filter selected should work by size exclusion of lead particles as opposed to lead adsorption. Filters should have tight pores (1-micron or less). NSF lists many such filters on its website.
 - Following replacement, retest the first-draw lead level after flushing the line 8-18 hours prior to testing to confirm that filter is successful in reducing lead levels.
 - Note: Point-of-Use (POU) Treatment Device systems may be subject to Department of Labor and Industry (DLI) or local administrative authority plan review and approval prior to installation. Contact DLI at 651-284-5063 for more information.

- Investigate further to determine the source of the lead responsible for an elevated lead level. Collecting multiple samples in a row can assist in determining the location of the lead-containing component (e.g. fittings for cold water supply lines). Samples should be collected upstream of the cold supply lines. Once the source is identified, remove, replace with lead-free component, and retest.
- If sampling indicates that fixture is the source of the elevated lead level, replace fixture with a "lead-free" fixture certified to NSF/ANSI 372 or NSF/ANSI 61-G. The *Reduction of Lead in Drinking Water Act* redefines "lead-free" as "not more than a weighted average of 0.25% lead when used with respect to wetted surfaces of pipes, pipe fittings, plumbing fittings, and fixtures." Effective January 4, 2014, drinking water system components sold or installed must adhere to this new requirement. A list of EPA Lead Free Certification Marks can be found here: <http://nepis.epa.gov/Exe/ZyPDF.cgi?Dockey=P100GRDZ.txt>
- Remove fixture from service by disconnecting it from the water supply and/or clearly mark water fixtures that are not for drinking or cooking.

The MDH recommends taking the following actions at 2 ppb to 20 ppb:

- Retest the sampled tap and attempt to more accurately determine the source of the lead; consider monitoring tap more frequently until the source of lead is found and removed;
- Consider the feasibility of flushing or other steps to minimize lead exposure, taking into account other actions that the school may already have in place;
- Make all test results and lead education materials accessible to community, such as on a website, or annual report, and available upon request.

5.0 Communication of Results and Follow-up Actions

Per Minnesota Statute 121A.335, a school district that has tested its buildings for the presence of lead shall make the results of the testing available to the public for review and must notify parents of the availability of the information. It is recommended that a copy of the district's Lead-in-Drinking Water Testing reports be made available to staff and the public through the district's administrative offices and district website.

Notification is accomplished by publishing a statement in the Back to School newsletter with the other health and safety notifications (e.g. asbestos, pesticides). For example notifications, see the MDE and MDH *Education and Communication Toolkit: Reducing Lead in Drinking Water, A Technical Guidance and Model Plan for Minnesota's Public Schools*, located on the MDH website.

The MDE and MDH guidance document states in their Model Plan that School Management should:

- Assign a designated person to be the contact;
- Notify affected individuals about the availability of the testing results within a reasonable time. School employees, students and parents should be informed and involved in the communication process. Results of initial and any follow-up testing should be easily accessible along with documentation of lead hazard reduction options. Posting the information on a website is preferred, but the information should also be available to those without easily accessible internet access. Examples of other information venues are: meetings, open houses, and public notices; and
- Identify and share specific activities pursued to correct any lead problems. Local health officials can assist in understanding potential health risks, technical assistance and communication strategies.

6.0 Recordkeeping

Lead-in-water testing reports are located and available for review in the District Office. See Appendix C for the most recent lead in water test results.

Rushford-Peterson Schools retains lead-in-water records for a minimum of five years.

Appendix A

EPA Factsheet: Lead in Drinking Water Coolers

EPA FACT SHEET: LEAD IN DRINKING WATER COOLERS

Protecting the nation's children from exposure to lead from school drinking water coolers is the primary goal of the Lead Contamination Control Act (LCCA), which was signed into law on October 31, 1988. EPA recommends that drinking water outlets--especially water coolers--in schools be tested to ensure that lead levels in the water are below 20 parts per billion.

This fact sheet will help school administrators address the problem of school water coolers that contain lead. It reflects current information as of February 1990. The information on the accompanying list will be updated periodically.

How To Identify Problems

First, identify which water coolers contain lead components; follow these steps as a minimum protocol.

- Inventory each cooler and note its brand, model, serial number, and year.
- Check the accompanying list to identify any coolers that are not lead free.
- Sample water from all outlets where lead contamination is most likely, especially coolers that are not lead free and those with lead-lined tanks. However, even coolers that are "lead free" may have high lead levels in their water due to other sources in the plumbing system and should be tested. Follow the sampling and testing protocols in the EPA booklet *Lead in Schools Drinking Water*. (See the box below, right.)
- Contact your State agency responsible for the LCCA program (see box below, right) for information and assistance on testing your water samples. Water samples should be sent only to certified laboratories that use the EPA-approved Graphite Furnace Atomic Absorption (AA) method. In some cases, the local water supplier, local or State department of health or environment, or the lab will collect and analyze the samples. In most cases, the lab will provide containers and instructions for collection. The charge for lab tests ranges from \$7 to \$30 per sample. In some States or localities, there may be funding available for testing.

What To Do If Problems Are Found

If the lead level of any fountain or outlet exceeds 20 parts per billion (ppb), take immediate action to reduce the level of contamination. Flushing outlets on a daily basis before school begins may sufficiently reduce exposures, especially if the problem is localized to a few outlets in a building. However, daily flushing may not be practical for water coolers.

Take follow-up samples from any outlet with lead levels above 20 ppb to pinpoint the source of the problem. Make sure to follow the instructions in the EPA booklet *Lead in School Drinking Water*. If you find a cooler to be the source of the lead, contact the distributor or manufacturer to determine how the problem may be corrected. If a cooler that is not lead free is responsible for high lead levels, removal may be necessary. The Consumer Product Safety Commission (CPSC) has the responsibility to issue an order to require manufacturers and importers to repair, replace or recall water coolers identified by EPA as having lead-lined tanks. Contact the CPSC Hotline (800/638-2772) to determine the status of their actions.

For More Information

Contact the State office listed below for information on identifying and correcting lead in drinking water problems. Contact the EPA Safe Drinking Water Hotline at 800/426-4791 for other information and for the booklet *Lead in Schools Drinking Water*.

Water Coolers With Lead-Lined Tanks

The following list of model numbers represents all of the drinking water coolers with lead-lined tanks that have been identified to date. The models listed here were selected because one or more of the units in that model series have been tested and found to have lead-lined tanks. These six models are made by the Halsey Taylor Company.

WM 8A
WT 8A

GC 10ACR
GC 10A

GC 5A
RWM 13A

Other Water Coolers Containing Lead

EBCO Manufacturing Company

EBCO has identified all pressure bubbler water coolers with shipping dates from 1962 through 1977 as having a bubbler valve containing lead, as defined by the LCCA. The units contain a single 50-50 tin-lead solder joint on the bubbler valve. Model numbers for those coolers in this category were not available.

The following EBCO models of pressure bubbler coolers produced from 1978 through 1981 contain one 50-50 tin-lead solder joint each:

CP3	DP7SM	DPM8H
CP10-50	DP10F	DP16M
DP20-50	CP3H	DP7S
DP13A	13P	DP7WM
DP7M	DP3RH	EP10F
DP13M-60	DP14A-50/60	CP10
CP5M	DP12N	DP20
DP14S	DPM8	DP8AH
DP5F	DP15M	C10E
CP3-50	DP5S	DP5M
7P	DP13SM	DP13M
DP3R	EP5F	CP3M
DP13A-50	CP5	DP13S
PX-10	13PL	DP7WMD
DP7MH	DP8A	WTC10
DP14M	DP10X	
DP15MW	DP15W	

Pressure bubbler water coolers manufactured by EBCO and marketed under the "Oasis" and "Kelvinator" brand names with the identified model numbers have been distributed in the U.S. In addition, EBCO indicated that "Aquarius" pressure bubbler water coolers are manufactured for distribution in foreign countries, including Canada. Although unlikely, it is conceivable that an "Aquarius" cooler with one of the model numbers listed above could have been transported into the U.S.

Halsey Taylor Company

Halsey Taylor reports using lead solder in these models of water cooler manufactured between 1978 and the last week of 1987.

WMA-I	SCWT/SCWT-A
SWA-I	DC/DHC-1
S3/5/10 D	BFC-4F/7F/4FS/7FS
S300/500/1000D	

In addition to these Halsey Taylor models, Halsey Taylor indicates that the following Haws brand coolers manufactured for Haws by Halsey Taylor from November 1984 through December 18, 1987, are not lead free because they contain two tin-lead solder joints. The model designations for these coolers are:

HC8WT	HC14W	HCBF7D
HC8WTH	HC4F	HCBF7HO
HC14WT	HC4FH	HWC7
HC14WTH	HC8F	HWC7D
HC14WL	HC8FH	HC2F
HC16WT	HC14F	HC2FH
HC4W	HC14FH	HC5F
HC6W	HC14FL	HC10F
HC8W	HCBF7	

Note: A number of water coolers have been deleted from the proposed list identifying them as not lead free. For information about these water coolers and others, refer to the January 18, 1990 Federal Register notice.

Appendix B

Testing Schedule

Lead-in-Water Testing Schedule Rushford-Peterson Schools

Buildings Included	Sampling Schedule
Rushford-Peterson School (K-12)	<p style="text-align: center;"><u>Last Test Date:</u> October 2017</p> <p style="text-align: center;"><u>Next Scheduled Testing:</u> FY2022</p>

Appendix C

Lead-in-Water Testing Results and Locations

November 13, 2017



Chuck Ehler
Rushford-Peterson School District
1000 Pine Meadows Lane, PO Box 627
Rushford, MN 55971

**RE: 2017 Rushford-Peterson School – Lead-in-Water Testing
IEA Project #201710829**

Dear Chuck:

At the request of Rushford-Peterson School District, IEA collected a total of fifty-nine (59) samples of drinking water from Rushford-Peterson School for lead analysis on October 18, 2017.

The purpose of the site sampling was to document lead levels in the sampled locations and compare them to the EPA action level of 20 parts per billion (ppb).

INTRODUCTION

The Lead Contamination Control Act (LCCA) of 1988 was created by the Environmental Protection Agency (EPA) to identify and reduce lead in drinking water. Both the EPA and the Minnesota Department of Health (MDH) recommend testing of potable water sources (water used for consumption) every five years for the presence of lead. Lead is a metal that usually enters drinking water through the distribution system, including pipes, solders, faucets, and valves. Lead levels in water may increase when the water is allowed to sit undisturbed in the system, such as in science, biology, or art areas. Exposure to lead is a significant health concern, especially to infants and young children whose growing bodies absorb lead more readily than adult bodies do. Lead exposure can cause delays in physical and/or mental development in children and damage to the brain, kidneys, nervous system, and red blood cells. The EPA and MDH recommend that action be taken at a specific fixture when the lead concentration exceeds the EPA's action level for schools of 20 parts per billion (ppb).

METHODOLOGY

IEA collected fifty-nine (59) first-draw samples of approximately 250 milliliters (ml). "First draw" means the samples are collected before the fixture is used or flushed during the day. The first-draw sample results reflect a worst-case scenario, i.e., the highest lead level that would be consumed by building occupants. Current protocol calls for flushing test locations 8-18 hours prior to sampling, which was completed by the school district's custodial staff.

Water samples were analyzed by Minnesota Valley Testing Laboratories (MVTL) in New Ulm, Minnesota, which uses EPA approved analytical methods and quality control/assurance procedures. Samples were analyzed using the ICP/MS EPA Method 200.8.

RESULTS & DISCUSSION

Analysis of the water samples showed lead concentrations ranged from below the level of detection (<0.05 ppb) to 5.08 ppb. Thus, lead levels were below the EPA Action Level of 20 ppb. The laboratory report is provided in Appendix B. Laboratory results are reported in micrograms per liter ($\mu\text{g/L}$) which is equivalent to parts per billion (ppb).

RECOMMENDATIONS

IEA recommends that a copy of the district's Lead-in-Drinking Water Testing Report be made available to staff and the public through the district's administrative offices.

As of July 1, 2018, all potable water fixtures used for consumption should be tested every 5 years as required by Minnesota State Law.

GENERAL COMMENTS

The analysis and opinions expressed in this report are based upon data obtained from Rushford-Peterson School District at the indicated locations. This report does not reflect variations in conditions that may occur across the site, property, or facility. Actual conditions may vary and may not become evident without further assessment.

The report is prepared for the exclusive use of our client for specific application to the project discussed and has been prepared in accordance with generally accepted Environmental Health & Safety practices. Other than as provided in the preceding sentence and in our Proposal #6219 dated July 6, 2017 regarding lead in water testing including the General Conditions attached thereto, no warranties are extended or made.

If you have any questions or would like further assistance in implementing any of the above recommendations, please do not hesitate to contact me at 763-315-7900.

Sincerely,

IEA, Inc.



Dan Fitch, CSR
EH&S Account Manager

Enc.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2 North German St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvtl.com



Report Date: 6 Nov 2017

HEIDI SOLBERG
IEA/BROOKLYN PARK
9201 W BDWY STE #600
BROOKLYN PARK MN 55445

Work Order #: 12-15975
Account #: 002190
Purchase Order #: 201710829

Date Received: 19 Oct 2017
Date Sampled: 18 Oct 2017
Time Sampled: 5:35
Temperature at Receipt: AMBIENT

PROJECT NAME: RUSHFORD PETERSON SCHOOL
PROJECT NUMBER: 201710829

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
17-A52558	101817RP-01 NORTH COMMONS BOTTLE FILLER	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52559	101817RP-02 NORTH COMMONS WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52560	101817RP-03 KITCHEN SINK	1.95 ug/L	15.0	2 Nov 17	RMV
17-A52561	101817RP-04 SOUTH COMMONS BOTTLE FILLER	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52562	101817RP-05 SOUTH COMMONS WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52563	101817RP-06 CONCESSIONS SINK	3.47 ug/L	15.0	2 Nov 17	RMV
17-A52564	101817RP-07 FITNESS CENTER BOTTLE FILLER	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52565	101817RP-08 FITNESS CENTER WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52566	101817RP-09 HALLWAY NEXT TO ROOM 127 BOTTLE FILLER	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52567	101817RP-10 HALLWAY NEXT TO ROOM 127 WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52568	101817RP-11 ROOM 127 SINK	3.26 ug/L	15.0	2 Nov 17	RMV
17-A52569	101817RP-12 ROOM 128 SINK	0.94 ug/L	15.0	2 Nov 17	RMV
17-A52570	101817RP-13 ROOM 146 SINK	1.37 ug/L	15.0	2 Nov 17	RMV
17-A52571	101817RP-14 ROOM 144 SINK	1.78 ug/L	15.0	2 Nov 17	RMV

Approved by:

Dan O'Connell, Chemistry Laboratory Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:

@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same in any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2 North German St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvttl.com



Report Date: 6 Nov 2017

HEIDI SOLBERG
IEA/BROOKLYN PARK
9201 W BDWY STE #600
BROOKLYN PARK MN 55445

Work Order #: 12-15975
Account #: 002190
Purchase Order #: 201710829

Date Received: 19 Oct 2017
Date Sampled: 18 Oct 2017
Time Sampled: 5:35
Temperature at Receipt: AMBIENT

PROJECT NAME: RUSHFORD PETERSON SCHOOL
PROJECT NUMBER: 201710829

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
17-A52572	101817RP-15 ROOM 143 SINK	1.41 ug/L	15.0	2 Nov 17	RMV
17-A52573	101817RP-16 ROOM 142 SINK	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52574	101817RP-17 ROOM 141 SINK	1.18 ug/L	15.0	2 Nov 17	RMV
17-A52575	101817RP-18 ROOM 139 SINK	1.02 ug/L	15.0	2 Nov 17	RMV
17-A52576	101817RP-19 ROOM 138 SINK	0.54 ug/L	15.0	2 Nov 17	RMV
17-A52577	101817RP-20 ROOM 137 SINK	1.82 ug/L	15.0	2 Nov 17	RMV
17-A52578	101817RP-21 ROOM 123 SINK	1.65 ug/L	15.0	2 Nov 17	RMV
17-A52579	101817RP-22 ROOM 122 SINK	2.75 ug/L	15.0	2 Nov 17	RMV
17-A52580	101817RP-23 ROOM 121 WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52581	101817RP-24 ROOM 121 SINK	1.17 ug/L	15.0	2 Nov 17	RMV
17-A52582	101817RP-25 ROOM 116 SINK	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52583	101817RP-26 ROOM 113 WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52584	101817RP-27 ROOM 113 SINK	1.32 ug/L	15.0	2 Nov 17	RMV
17-A52585	101817RP-28 ROOM 110 WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52586	101817RP-29 ROOM 110 SINK	1.40 ug/L	15.0	2 Nov 17	RMV

Approved by: 
Dan O'Connell, Chemistry Laboratory Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:
@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2 North German St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvttl.com



Report Date: 6 Nov 2017

HEIDI SOLBERG
IEA/BROOKLYN PARK
9201 W BDWY STE #600
BROOKLYN PARK MN 55445

Work Order #: 12-15975
Account #: 002190
Purchase Order #: 201710829

Date Received: 19 Oct 2017
Date Sampled: 18 Oct 2017
Time Sampled: 5:35
Temperature at Receipt: AMBIENT

PROJECT NAME: RUSHFORD PETERSON SCHOOL
PROJECT NUMBER: 201710829

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
17-A52587	101817RP-30 ROOM 109 WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52588	101817RP-31 ROOM 109 SINK	1.16 ug/L	15.0	2 Nov 17	RMV
17-A52589	101817RP-32 ROOM 106 SINK	1.43 ug/L	15.0	2 Nov 17	RMV
17-A52590	101817RP-33 ROOM 100 SINK	1.02 ug/L	15.0	2 Nov 17	RMV
17-A52591	101817RP-34 DISTRICT OFFICE SINK	0.55 ug/L	15.0	2 Nov 17	RMV
17-A52592	101817RP-35 HEALTH SERVICES (95) SINK	0.51 ug/L	15.0	2 Nov 17	RMV
17-A52593	101817RP-36 FACS ROOM WEST SINK	1.91 ug/L	15.0	2 Nov 17	RMV
17-A52594	101817RP-37 FACS ROOM NW SINK	1.39 ug/L	15.0	2 Nov 17	RMV
17-A52595	101817RP-38 FACS ROOM N SINK	1.63 ug/L	15.0	2 Nov 17	RMV
17-A52596	101817RP-39 FACS ROOM NE SINK	1.38 ug/L	15.0	2 Nov 17	RMV
17-A52597	101817RP-40 FACS ROOM E SINK	1.07 ug/L	15.0	2 Nov 17	RMV
17-A52598	101817RP-41 FACS ROOM SE SINK	1.03 ug/L	15.0	2 Nov 17	RMV
17-A52599	101817RP-42 FACS ROOM S SINK	1.29 ug/L	15.0	2 Nov 17	RMV
17-A52600	101817RP-43 HALLWAY NEXT TO ROOM 219 BOTTLE FILLER	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52601	101817RP-44 HALLWAY NEXT TO ROOM 219 WC	< 0.5 ug/L	15.0	2 Nov 17	RMV

Approved by: 
Dan O'Connell, Chemistry Laboratory Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:

- @ = Due to sample matrix
- ! = Due to sample quantity
- # = Due to concentration of other analytes
- + = Due to internal standard response

~~CERTIFICATION: MN LAB # 027-015-135 HI LAB # 000447600 ND NIOSH # 1012 N ND WH/BNL # 040~~
MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2 North German St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382 3885
www.mvttl.com



Report Date: 6 Nov 2017

HEIDI SOLBERG
IEA/BROOKLYN PARK
9201 W BDWY STE #600
BROOKLYN PARK MN 55445

Work Order #: 12-15975
Account #: 002190
Purchase Order #: 201710829

Date Received: 19 Oct 2017
Date Sampled: 18 Oct 2017
Time Sampled: 5:35
Temperature at Receipt: AMBIENT

PROJECT NAME: RUSHFORD PETERSON SCHOOL
PROJECT NUMBER: 201710829

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
17-A52602	101817RP-45 MIDDLE SCHOOL COMMONS BOTTLE FILLER	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52603	101817RP-46 MIDDLE SCHOOL COMMONS WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52604	101817RP-47 ROOM 202 SINK	1.20 ug/L	15.0	2 Nov 17	RMV
17-A52605	101817RP-48 BAND ROOM (65) WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52606	101817RP-49 MUSIC ROOM (57) WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52607	101817RP-50 WRESTLING ROOM (77) BOTTLE FILLER	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52608	101817RP-51 WRESTLING ROOM (77) WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52609	101817RP-52 AG ROOM (76) SINK	0.84 ug/L	15.0	2 Nov 17	RMV
17-A52610	101817RP-53 BASEMENT HALLWAY BOTTLE FILLER	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52611	101817RP-54 BASEMENT HALLWAY WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52612	101817RP-55 GIRLS LOCKER ROOM N WC	< 0.5 ug/L	15.0	2 Nov 17	RMV
17-A52613	101817RP-56 GIRLS LOCKER ROOM S WC	5.08 ug/L	15.0	2 Nov 17	RMV
17-A52614	101817RP-57 BOYS LOCKER ROOM N WC	0.69 ug/L	15.0	2 Nov 17	RMV

Approved by: 
Dan O'Connell, Chemistry Laboratory Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:
@ = Due to sample matrix # = Due to concentration of other analytes
! = Due to sample quantity + = Due to internal standard response

~~CERTIFICATION: MN LAB # 027-015-125 WI LAB # 000447600 ND MICRO # 1012-N ND NW/BDWY # 046~~
MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2 North German St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.mvttl.com



Report Date: 6 Nov 2017

HEIDI SOLBERG
IEA/BROOKLYN PARK
9201 W BDWY STE #600
BROOKLYN PARK, MN 55445

Work Order #: 12-15975
Account #: 002190
Purchase Order #: 201710829

Date Received: 19 Oct 2017
Date Sampled: 18 Oct 2017
Time Sampled: 5:35
Temperature at Receipt: AMBIENT

PROJECT NAME: RUSHFORD PETERSON SCHOOL
PROJECT NUMBER: 201710829

LAB NUMBER	SAMPLE DESCRIPTION	LEAD RESULTS	MCL	DATE ANALYZED	ANALYST
17-A52615	101817RP-58 BOYS LOCKER ROOM S WC	1.39 ug/L	15.0	2 Nov 17	RMV
17-A52616	101817RP-59 ROOM 140 SINK	1.01 ug/L	15.0	2 Nov 17	RMV

Approved by: 
Dan O'Connell, Chemistry Laboratory Manager New Ulm, MN

Analyses performed under our Minnesota Department of Health Accreditation conform to the current TNI standards.

The reporting limit was elevated for any analyte requiring a dilution as coded below:




- @ = Due to sample matrix
- ! = Due to sample quantity
- # = Due to concentration of other analytes
- + = Due to internal standard response

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same as any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Appendix D

Recommended Lead Hazard Reduction Options

Recommended Lead Hazard Reduction Options

Lead Level At The Tap	Lead Hazard Reduction Options
<p data-bbox="240 407 418 470">< 2 ppb or Non-Detected</p> 	<ul data-bbox="483 428 1360 554" style="list-style-type: none"> • Lead was not detected. Tap may be used as normal; • Record result and test again in 5 years; and • Make all test results and lead education materials accessible to the community, such as on a website, or annual report, and available upon request.
<p data-bbox="240 785 418 816">2 ppb to 20 ppb*</p> 	<p data-bbox="440 590 1375 680">The tap may be used for cooking and drinking water while steps are taken to reduce overall exposure. A higher number of taps with elevated results increases the urgency to implement hazard reduction.</p> <p data-bbox="440 701 613 722">Options include:</p> <ul data-bbox="483 743 1360 995" style="list-style-type: none"> • Retest the sample tap and attempt to more accurately determine the source of the lead; consider monitoring tap more frequently until the source of lead is found and removed; • Consider the feasibility of flushing or other steps to minimize lead exposure, including limiting softened water supplies to hot water taps only, taking into account other actions that the school may already have in place; • Make all test results and lead education materials accessible to the community, such as on a website, or annual report, and available upon request.
<p data-bbox="272 1341 386 1373">> 20 ppb*</p> 	<p data-bbox="440 1062 1268 1121">Action should be taken to reduce exposure. The specific action(s) taken will be dependent on individual school conditions.</p> <p data-bbox="440 1142 613 1163">Options include:</p> <ul data-bbox="483 1184 1375 1562" style="list-style-type: none"> • Remove tap from service until problem is demonstrably corrected by replacement, a flushing program, filtration, or treatment; • Do not use tap for cooking or drinking water; • Retest the tap and attempt to determine the source of the lead; If the tap is not replaced, consider monitoring tap more frequently, such as annually, until the source of lead is found and removed; • Implement a flushing protocol or other lead hazard reduction option; sampling should be use to evaluate effectiveness; • Make all test results and lead education materials accessible to the community, such as on a website, or annual report, and available upon request; and • Provide targeted communication and education to individuals, parents, and staff members that routinely use that tap.

*established by EPA 3Ts guidance; if EPA amends, Table 3 will be adjusted to be consistent with new value

Appendix E

Parent Notification (Example)

LEAD-IN-WATER ANNUAL NOTICE

Minnesota Statute 121A.335 requires public school buildings serving kindergarten through grade 12 to test for lead in water every 5 years. This statute also requires school districts to make the results of the testing available to the public for review and to notify parents of the availability of the information.

Rushford-Peterson Public School District has a lead in water management plan and testing program that complies with Minnesota Statute 121A.335, as well as recommendations from the Environmental Protection Agency's (EPA's) Lead Contamination Control Act (LCCA) of 1988 and the Minnesota Department of Health (MDH).

For more information on the district's lead in water testing program, please contact Chuck Ehler, Superintendent at 507-864-7785.