

BUILDINGS/GROUNDS & TRANSPORTATION REPORT

Date: February 22, 2021
To: Board of Education
From: Jeff Stauder

BUILDINGS/GROUNDS

Facilities Committee

The committee did not meet.

Roof price and Photos

As of today I still do not have an estimate for the repair of the roof at the high school. I do however have pictures that were sent to me and I have attached them. As soon as I get the estimate, I will bring it to the Board.

Gym Floor

I received a proposal from Kiefer USA for the replacement of the gym floor. The estimate is attached. The price was \$109,600. They also added an option to put our logo in the center of the floor for an additional \$14,280. With this coming in over \$50,000, we will need to put this out for bid. I will get to work on this and hope to have something for the Board to approve by the March meeting. I would like to move on this quickly so that we can get this started in early June.

Tree Removal \$1650

We had two trees fall recently, one at the high school and one at Lincoln. I am having Hardy Tree Service cut them up and remove them.

Lincoln Boiler

We have a circulating pump on the boiler at Lincoln that has seals out and also a bad motor. Xcell Mechanical is going to repair them. I do not have a price to give you as of today but it should be around \$2,500.

Six Month Asbestos Survey

Our six month survey was done on February 18th. There were a few changes made due to some asbestos removal. The changes have been entered in the asbestos management plan books.