

MAINTENANCE REPORT  
FACILITIES/CONSTRUCTION REPORT  
MARCH 2019

Submitted by: Reid Reagan

Maintenance staff has been busy with snow removal. Next obstacle is clearing snow before flooding/run-off at all schools. Assist Food Services distributing of clean water to the schools due to water/sewer breaks in town. In addition we are preparing the outdoor facilities for the spring sporting activities. The staff has responded to 80 work orders.

**HIGH SCHOOL:**

Sewer line plugged from the main offices to C-wing, line was froze up in the drive-up entrance to the school, between building and sewer main, service restored. Hauled all tables/chairs to gym for CRT testing. Hooked up new plasma cutter in Auto Shop, installed electrical outlet for Powermatic in Wood Shop. Repaired broken floor board in gym bleacher. Installed new circulation pump for VO/AG classrooms.

**BMS:**

Responded to fire alarm on 3/14, false alarm due to dirty smoke detector.

**NAPI:**

Remove snow from playground. Repaired restrooms in the boys 4<sup>th</sup> and 6<sup>th</sup> grade hallways.

**BES:**

Made the corrective actions to comply with the recent safety compliance inspection from State of Montana.

**KWB:**

Made the corrective actions to comply with the recent safety compliance inspection from State of Montana. Assist with the Fire/Evacuation drill, pull and reset fire alarm.

**VC:**

Sewer plugged in downstairs restrooms causing janitors closet sink to back-up, service restored . Assist with the Fire/Evacuation drill, pull and reset fire alarm.

BABB:

Restored water service to rental trailer next to school.

ADMINISTRATION:

Cleared the frozen sewer pipes out in the street, system restored.