

Old Fieldhouse Demo

I was asked to get a price for tearing down the old field house at the Admin Building. I received a quote from Roof Masters for \$28,657.14 to demo and haul off all debris. This does not include asbestos abatement, which will be a separate company doing that. I asked for a quote and haven't received that yet. More information to come.



Team 1845
PO Box 875
Hallsville, TX 75650
OR
7260 IH-20 North Service Rd
West
Hallsville, TX 75650
Phone: (903) 660-2309

Company Representative
Wesley Campbell
Phone: (903) 578-5946
wesley@team1845.com

10/15/2024
Claim Information

Matt Tucker Demo
324 West Walnut Street
Hallsville, TX 75650
(903) 578-0743

Job: Matt Tucker Demo

Demo of existing old Fieldhouse

	Qty	Unit
Demo of old Fieldhouse	1.00	EA
DEMOLITION: Remove brick and cinderblock structure also heavy metal components such as wall panels I-beams and angle joist.		
HAUL AWAY OF DEBRIS: Transport demolished materials off of job site. Trucks will be provided for transporting materials to disposal site. Roll off containers will be on site for efficient, loading and transport of debris.		
EQUIPMENT AND LABOR PROVIDED: Excavator and skid steer three days for the duration of the project.		
NOT INCLUDED IN ON THIS ESTIMATE: Plumbing, gas and water disconnections and capped of lines are outside of the scope of work above.		

\$28,657.14

TOTAL \$28,657.14

Starting at \$284/month with **Acorn** FINANCE • **APPLY**

Company Authorized Signature

Date

Customer Signature

Date

Customer Signature

Date



TITLE


OLD FIELD HOUSE
PIPING ASBESTOS
SAMPLE LOCATIONS

LOCATION

HALLSVILLE INDEPENDENT
SCHOOL DISTRICT
ELEMENTARY I
HALLSVILLE, TEXAS
2022 ASBESTOS REINSPECTION

LEGEND


- 001 POSITIVE FOR ACBM
- 001 NEGATIVE FOR ACBM
- 001 RETESTED & FOUND NOT TO CONTAIN ASBESTOS



HV-16-165-011

OLD FIELD HOUSE

KEY PLAN



PROJECT NO.

SA00162

SCALE
1" = 16'

PAGE

1

DRAWN BY
BB

SHEET

A - 8.5 X 11

DATE
04/08/23

Sample ID

HV-16-265-011


Material Description

2" Horizontal Pipe with Green Cloth
Wrap, White Cardboard Insulation

Asbestos
% Type

35% Chrysotile

L:\Drawings\Asbestos\Independent School District\2022 HVS Year Reinspection\Main Campus\Formerly Elementary\MSJ081821\VP.dwg



OLD FIELD HOUSE

TITLE

OLD FIELD HOUSE
PIPING ASBESTOS
HOMOGENEOUS AREAS

LOCATION

HALLSVILLE INDEPENDENT
SCHOOL DISTRICT
ELEMENTARY 1
HALLSVILLE, TEXAS
2022 ASBESTOS REINSPECTION


LEGEND



HMA-06 PIPING INSULATION
APRX. 75 LIN FT



KEY PLAN



PROJECT NO.

SA00162

SCALE

1" = 15'

PAGE

1

DRAWN BY

BB

SHEET

A - 0.5 X 11

DATE

04/05/23