

**Southeast Extinguisher Service Inc.**

8319 Airport Blvd  
 Juneau AK 99801  
 907-790-2522

**Fire Extinguishers**

**Service History**

Order # 37686

**JOB LOCATION**

Craig City School District  
 School Buses  
 PO Box 800  
 Craig AK 99921  
 Service Date: 8/15/2024

**CLIENT**

Same

**CONTACT**

**TECHNICIAN**

CM

Num S/N	Location	Size / Type	Mfg Date	Hydro Test	6 Year	Bar Code	Timestamp
1 MJ-852594	Bus 1	5 ABC	1994	2023		MJ-852594	8/15/2024 3:41:37 PM
2 I06665105	Bus 2	5 ABC	2023			I06665105	8/15/2024 3:35:11 PM
3 I21006997	Bus 3	5 ABC	2024			I21006997	8/15/2024 3:39:05 PM
4 I06626837	Bus 4	5 ABC	2023			I06626837	8/15/2024 3:44:43 PM

Extinguisher Work Summary as of 8/15/2024

	Hydro Test	6 Year	Annual	Monthly	Recharge	New	5 Year Visual	Other	Totals
5 ABC	0	0	4	0	0	0	0	0	4
Totals	0	0	4	0	0	0	0	0	4

**Annual Fire Extinguisher Inspection**

**I. NFPA 10**

PASS FAIL NA

Maintenance and Inspection of fire extinguishers shall include a check of at least the following items:

- 1. Located in designated place NFPA 10 6.1.2 - 6.1.3 & 7.2.2(1)  PASS  FAIL  NA
- 2. No obstructions to access or visibility NFPA 10 6.1.3.3 & 7.2.2(2)(3)  PASS  FAIL  NA
- 3. Operating instructions on nameplate legible and facing outward NFPA 10 7.3.2.1  PASS  FAIL  NA
- 4. Pull pin operates correctly and new tamper seal installed NFPA 10 7.3.2.2 - 7.3.2.2.2  PASS  FAIL  NA
- 5. Fullness determined by weighing or "hefting." NFPA 10 7.3.2.1 & 7.2.2(5)  PASS  FAIL  NA
- 6. Examined for obvious physical damage, corrosion, leakage, or clogged nozzle NFPA 10 7.3.2.1  PASS  FAIL  NA
- 7. Pressure gauge reading or indicator in the operable range or position NFPA 10 7.2.2(4)  PASS  FAIL  NA
- 8. Extinguisher properly protected from physical damage such as from impact, vibration or environment NFPA 10 6.1.3.7  PASS  FAIL  NA
- 9. Correct extinguisher for application NFPA 10 5.1-5.6  PASS  FAIL  NA
- 10. Correct hanger or bracket NFPA 10 6.1.3.4  PASS  FAIL  NA
- 11. Hanger or bracket secure and mounted at correct height NFPA 10 6.1.3.4 - 6.1.3.8  PASS  FAIL  NA
- 12. For wheeled units, the condition of the tires, wheels, carriage, hose, and nozzle checked NFPA 10 7.7 & 7.2.2(6)  PASS  FAIL  NA

**II. Action Recommended/Coverage Notes**

OK FAIL NA

- 1. Property has proper coverage  OK  FAIL  NA
- 2. Delicate electronic equipment has proper coverage NFPA 5.5.6  OK  FAIL  NA
- 3. Additional notes on inspection  OK  FAIL  NA

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS

**Southeast Extinguisher Service Inc.**

8319 Airport Blvd  
Juneau AK 99801  
907-790-2522

**Fire Extinguishers**

**Service History**

Order # 37686

**JOB LOCATION**

Craig City School District  
School Buses  
PO Box 800  
Craig AK 99921

**CLIENT**

Same

**Annual Fire Extinguisher Inspection**

**II. Action Recommended/Coverage Notes**

OK   FAIL   NA

The maintenance and recharging of fire extinguishers is based on NFPA 10-2010, 7.1.2; 7.2.2; 7.2.4; 7.3.1, Installation of Portable Fire Extinguishers, and Alaska statutes and is approved by the local Authority Having Jurisdiction. This inspection is not an engineering evaluation of the fire extinguishers.

ALL WORK DONE IN ACCORDANCE WITH N.F.P.A. STANDARDS