



Medford School District ISD #763

Maintenance Report

October 2024

Maintenance

- New steer tires on loader tractor 10.9.24
- Science room (208) eyewash station repaired
- Roof top units
 - RTU#4 Elementary VFD replaced 9.25.24
 - Girls Locker room AAH1- replaced motor connector 9.25.24
AAH1-Supply air motor sent out for rebuild
 - Boys Locker room AAH2- Motor replaced 10.11.24
- Dishwasher repaired- Final Temp not reaching 180F

Inspections

- AED check
- Mock OSHA completed 10.14.24

Training

- HVAC training with SCR completed 09.25.24
- Attended MASMS (Facility Management) conference 10.3.24

Projects

- Currently working on cleaning out back of shed
- Moving furniture from Auditorium to Back of shed

Respectfully submitted, Mike Prondzinski