

Facilities Work Progress Report for New Berlin Elementary

Board Report for August/September 2022

Work to Begin or in Progress	Description	Update
Had Gym floor refinished		
AEC completed Fire Ext. and Kitchen hood insoections, moved nozzles above grill per Fire Marshall		
Sprinkler Inspection complete		
Elevator Inspection complete [handicap stage lift]		
Had parking lot restriped. Was faded		
Repaired two GEO leaks, one in Dist office ceiling, other in Green hall ceiling		
Replaced a couple of bad Exit lights		
S&W completed sidewalk project and gym entrance. waiting on bridge railing to be 100% complete		
Repair parking lot Light system programs, replaced photo eye		
Ordered and Installed all current classroom needs for 22-23 school year	Tables,Chairs, cubbies, etc.	
Bleacher Inspection completed		
Backflo Inspection's completed		
Repaired floor scrubber		
replaced bad outlet room 113		
Installed permanent sound system in Multipurpose room with some stuff we already had. Only had	to order Amp and mixer to complete	
cleaned out the only storage room we had and auctioned surplus desk/chairs etc	had mainly been stored since consilidation when	building opened in 2009. no more storage room
repair cooler in Kitchen, wasn't cooling		
preparing to install two large umbrellas in KG playground purchased with pre-k grant for shade		
Fire Alarm system inspection completed		
assist IT in installing key fob access to all KG outside doors and pplayground gate		
preparing for ROE inspection on Monday 9-19-22		
Had grease traps pumped		
Had controller replaced in 1 heat pump not that was not communicating with computer controller		
numerous flush module repairs		
Daily lunch duty		
serviced rooftop units		
replaced several lighting ballast		