Facilities Report October 2025

- 1. Put three new windows in brown garage replacing the broken ones
- 2. Painted Handicap signs on West parking lot
- 3. Repaired door, had to put new hardware on it and glue
- 4. Change all burnt out lights in all of the entries outside around the school
- 5. Put new wires on air compressor and got it working again
- 6. Took girls bathroom sink apart because it was leaking and had broken parts, used water lines and clamps from my house to fix it
- 7. Moved TV's from room to room and mounted on the walls
- 8. Put the boilers back together and got chemicals measured and filled, took about a week
- 9. Two pumps froze up on the water feed, so I took apart and fixed them. Saved the school about \$1,000
- 10. Replaced all the burnt out light bulbs in all the hallways, about 40 bulbs
- 11. Replaced stained ceiling tiles
- 12. Started boilers and pump, water loops Oct 20th