



**Dalton Refrigeration**  
Anchorage Mission Control  
6320 Quinhagak St.  
Anchorage, AK 99507  
(907) 240-4440

## Sales Order 862950

SALESPERSON Dallas Dalton  
dallasdalton@drefrigeration.com  
WORK ORDER 1552295

### SHIP TO

North Slope Borough School District  
(907) 852-9763

### BILL TO (#1149040)

North Slope Borough School District  
(907) 852-9763

### CUST PO

CONTACT Jill Crooks Jill.Crooks@nsbsd.org (907) 852-9763

SHIP OUT Will Call

DROP SHIP No

#	PART	DESCRIPTION	QTY	B/O	FILLED	RATE	DISC	NET	EXT
	Machine	Work #1552295 performed on RACK COOLERE/freezer barrow: Hours: 0			1.00				0.00
	NOTE	Repairs on all coolers/freezers in Barrow			1.00				0.00
1	JOB	(DRF) ESTIMATE	0.00			0.00		0.00	0.00
	COMPLAINT	Barrow repairs on coolers, freezers, in middle school and elementary school and MO							
	CORRECTION	Replace compressor in middle school, replace suction vibrasorber.  Replace accumulator tank at MO, leak test and finish repairs.  Elementry school, Leak check systems, repair all leaks, drain oil out of freezer unit and repair unit.							
2	OUT OF TOWN - DAILY RATE	(DRF) Labor for ESTIMATE	3.00		3.00	2,300.00		2,300.00	6,900.00

### PAYMENT

### DETAILS

### DATE

### AMT

### COMMENTS

SUBTOTAL	6,900.00
<b>TOTAL</b>	<b>6,900.00</b>
PAYMENTS	0.00
<b>BALANCE DUE</b>	<b>6,900.00</b>

**ACCEPTANCE:** \_\_\_\_\_ **DATE:** \_\_\_\_\_

Thank you for your Business