

Facilities Report  
December 2025

1. Fixed a vinyl tear in nurses room
2. Fixed a white board stand in girls coach
3. Worked on heater in entry to get it working
4. Filled in at lunch doing the point of sale several times this month
5. Fixed a urinal that was broken on 11/14, had to put a new flusher on it 200
6. Put four pieces of flashing back on the roof from a bad storm this Summer, brought roofing screws and tools from home
7. Worked on playground - fixed benches
8. Fixed bathroom sink the boys bathroom
9. MIST - Our insurance came and did a walkabout and gave me a list of safety hazards
10. Fixed sink and leak in the sink
11. Changed an outlet to a ground fault one in home ec room
12. Painted and reattached the arm bench in the fitness center
13. Got the list done for insurance inspector
14. Got the heat working in entry 4
15. Worked on gym floor, it took three days to sand, clean and to put finish on it
16. Summit was here and did the semi annual sprinkler inspection-all good
17. Pye Barker was here and did the kitchen semi annual Ansul inspection-all good
18. Replaced more ceiling tiles
19. Painted the styrofoam in the storage room with fire proof paint
20. Fixed two leaking toilets, had to put vacuum breakers in them
21. Replaced light switch in class room
22. Fixed gym door, took ½ a day
23. Ziegler was here to do the six month maintenance and inspection