



ALPENA COUNTY E-911 DIRECTOR

720 WEST CHISHOLM ST. - SUITE 13, ALPENA, MI 49707 • 354-9821/354-9111

Date: 02/25/2021

To: Finance Committee

From: Mark Hall, Emergency Services Coordinator & 911 Director

RE: Power Outlet Upgrade 911 Center


During the radio upgrade project, it was found that a good portion of the consoles were running on multiple power stripes, some of which had been plugged into each other. The installation team from Motorola was concerned about overload and potential fire concerns.

The decision was made to call in Thunder Bay Electric to evaluate the situation. Tim Modrzynski concurs with the above assessment and added that we should also be concerned about low voltage to all components.

Please see attached quote in the amount of \$4,845.00 to correct the deficiency. I am requesting these funds to come out of the Building and Grounds Fund.

Thank you for your consideration,

Mark Hall


Alpena County Emergency Services Coordinator & 911 Director



1693 M-32 West, P.O. Box 472
Alpena, MI 49707
Phone: (989) 354-2840
www.thunderbayelectric.com

Full Service Electrical Contractor

February 19, 2021

Mr. Mark Hall
County of Alpena
720 W. Chisholm Street
Alpena, MI 49707

Re: 911 Circuits

Mark:

Thunder Bay Electric, Inc. is pleased to provide you with the following quotation for all parts and labor necessary for the installation of new 4000 series Wiremold on top of a movable desk portion. TBE to install Wiremold for installation of six (6) double duplex receptacles at each of the three dispatch stations. All work to meet National Electric Code.

Total Price: \$4,845.00

Thank you for the opportunity to provide you with this quotation. If you have any questions, please feel free to call.

Sincerely,

Tim Modrzynski