



**GOVERNING BOARD AGENDA ITEM
AMPHITHEATER UNIFIED SCHOOL DISTRICT NO. 10**

DATE OF MEETING: January 22, 2013

TITLE: Approval for Underground Storage Tank (UST) Emergency Funding from the SFB, Application Number 330

BACKGROUND:

Through our onsite monitoring system that monitors our fuel tanks, Underground Storage Tanks (UST) we discovered a discrepancy on our quantity of fuel that is stored. Further monitoring validated a leak to our UST of regular gas. We had the tank tested and it was confirmed. After investigation we confirmed the tank had a leak. We contacted the Arizona Department of Environmental Quality (ADEQ), Owens Corning, the tank manufacturer, and the Trust. We have applied to the School Facilities Board (SFB) and received an application for funding. Consent and authorization for funding are required for the application to be enforced.

RECOMMENDATION:

It is the recommendation of the Administration that the application to the SFB for emergency funding be approved.

INITIATED BY:

A handwritten signature in cursive script, appearing to read "Doug Aho".

Doug Aho, Executive Manger Operational Support

Date: January 22, 2013

A handwritten signature in cursive script, appearing to read "Patrick Nelson".

Patrick Nelson, Superintendent