

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER Pana Community Unit School District No. 8	COUNTY Christian/Montgomery
FACILITY NAME Washington School	FACILITY LOCATION 200 South Sherman Street, Pana

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 01/10/2023 by Dean Keller.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
24	Administration and General	Extension cords in cafeteria, office in library,
25	Administration and General	Downstairs janitor closet needs gfi.
97	Classrooms	Limit artwork to 50% of wall-space. Arrange seats in classrooms to maximize egress (move chairs and desks away from exit areas.
122	Elevator and Conveying Systems	Inspected no certificate yet