

# Craig City School District

P.O. Box 800, Craig, Alaska 99921  
www.craigschools.com  
Phone (907) 826.3274  
FAX (907) 826.3322

Jackie Hanson, Superintendent  
Christy House, Elem./MS Principal  
Josh Andrews, HS & PACE Principal

## CCSD Maintenance Report May 2026

1 May - Rear brakes CES/CMS Van 1 – replaced rotor, caliper, and pads.


1 May - We borrowed the city's mower and got about halfway finished with the ballfield when we promptly broke their mower as well. (Apparently, we are good at breaking mowers; we have 3 that are inoperable – hence the borrowing)



5 May 2026 – Boiler 2 pressure valve failed, and the glycol tank overflowed into the hallway. (Last flood of the 2026 flood season).



6 May 2026 – Replaced pressure valve on boiler 2.



6 May 2026 – NO ALARMS and happy dances were had by all. (and by all, I mean myself)

6 May 2026 – Hot water in CMS gym showers is on and working. (pro tip – surprising your coworker while validating water pressure is not always a good idea)



15 May 2026 – City repaired their mower; it was sunny, so we promptly borrowed their mower again. We managed to get the ballfield and part of the front of the HS completed before we had to give it back. We have attempted to mitigate the dandelion invasion with weed eaters and a push mower. The weather and wet grass have made this effort less than successful – like the dandelions, we will persist.

20 May 2026 – In this month's version of 'How to get Brent into the manlift' – may I present the Great Eggdrop of 2026.



As of Today (Friday, the 22nd of May), we have had zero issues with the high school boiler. No more flooding, and pressure has been holding steady without human intervention.



We continue to 'dial in' settings for our system. We are at the point where we can make minor adjustments based on individual preferences (classrooms/offices) while still turning off utilities when not in use.